

# **PROBLEM SUMMARY**

Sample Rating Trend

ISO


Machine Id

# KAESER CSD 75 7939710 (S/N 1230)


Component

Compressor

NOT GIVEN (--- GAL)



### **COMPONENT CONDITION SUMMARY**



#### RECOMMENDATION

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS							
Sample Status			ATTENTION	ATTENTION			
Particles >6µm	ASTM D7647	>1300	<b>1604</b>	721			
Oil Cleanliness	ISO 4406 (c)	>/17/13	<b>20/18/13</b>	▲ 18/17/14			

Customer Id: MOCVER Sample No.: KCPA005947 Lab Number: 05926722 Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS						
Action	Status	Date	Done By	Description		
Change Fluid			?	Oil and filter change at the time of sampling has been noted.		
Change Filter			?	Oil and filter change at the time of sampling has been noted.		

### HISTORICAL DIAGNOSIS

27 May 2022 Diag: Angela Borella





Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.





# **OIL ANALYSIS REPORT**



# KAESER CSD 75 7939710 (S/N 1230)

Compressor

NOT GIVEN (--- GAL)

### **DIAGNOSIS**

#### Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.

#### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			May <b>2</b> 022	Aug2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA005947	KCP44511	
Sample Date		Client Info		16 Aug 2023	27 May 2022	
Machine Age	hrs	Client Info		9613	3160	
Oil Age	hrs	Client Info		8007	0	
Oil Changed		Client Info		Changed	Changed	
Sample Status				ATTENTION	ATTENTION	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	2	3	
Chromium	ppm	ASTM D5185m	>10	<1	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	<1	0	
Silver	ppm	ASTM D5185m	>2	0	<1	
Aluminum	ppm	ASTM D5185m	>10	4	2	
Lead	ppm	ASTM D5185m	>10	0	0	
Copper	ppm	ASTM D5185m	>50	6	30	
Tin	ppm	ASTM D5185m	>10	<1	<1	
Vanadium	ppm	ASTM D5185m		<1	0	
Cadmium	ppm	ASTM D5185m		<1	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m		0	0	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		<1	0	
Magnesium	ppm	ASTM D5185m		2	<1	
Calcium	ppm	ASTM D5185m		0	0	
Phosphorus	ppm	ASTM D5185m		158	191	
Zinc	ppm	ASTM D5185m		158	234	
Sulfur	ppm	ASTM D5185m		1698	3891	
CONTAMINANTS	)	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	
Sodium	ppm	ASTM D5185m		<1	0	
Potassium	ppm	ASTM D5185m	>20	2	<1	
Water	%	ASTM D6304	>0.05	0.001	0.002	
ppm Water	ppm	ASTM D6304	>500	14.1	21.5	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		8204	2371	
Particles >6µm		ASTM D7647	>1300	<u></u> 1604	721	
Particles >14µm		ASTM D7647	>80	57	<u>\$5</u>	
Particles >21µm		ASTM D7647	>20	8	23	
Particles >38µm		ASTM D7647	>4	0	1	
Particles >71μm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>^</u> 20/18/13	<b>▲</b> 18/17/14	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
A : 151 1 (AND)	1/011/	ACTM DODAE		0.42	0.50	

Acid Number (AN)

mg KOH/g ASTM D8045

0.58


0.43



## **OIL ANALYSIS REPORT**



Diagnostician : Don Baldridge



Certificate L2367

**Unique Number** 

: 10606669

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Test Package : IND 2 ( Additional Tests: KF, PrtCount )

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

US 90058

T: F:

Contact: Service Manager