


# **PROBLEM SUMMARY**

# Sample Rating Trend

#### Machine Id 8180369 (S/N 1797) Component

Compressor Fluid KAESER SIGMA (OEM) M-460 (--- GAL)

# COMPONENT CONDITION SUMMARY



# RECOMMENDATION

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

#### **PROBLEMATIC TEST RESULTS** Sample Status ABNORMAL ABNORMAL **ATTENTION** Particles >6µm ASTM D7647 >1300 53227 **11019** ▲ 1313 - 🔺 Particles >14µm ASTM D7647 >80 3817 ▲ 600 57 191 Particles >21µm ASTM D7647 >20 43 17 **Oil Cleanliness** ISO 4406 (c) >--/17/13 **4/23/19** 22/21/16 ▲ 18/13

Customer Id: BELAGA Sample No.: KCPA004009 Lab Number: 05926738 Test Package: IND 2



To manage this report scan the QR code

*To discuss the diagnosis or test data:* Don Baldridge +1 <u>don.b505@comcast.net</u>

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS							
Action	Status	Date	Done By	Description			
Change Fluid			?	Oil and filter change at the time of sampling has been noted.			
Change Filter			?	Oil and filter change at the time of sampling has been noted.			

# HISTORICAL DIAGNOSIS



# 17 Nov 2022 Diag: Doug Bogart

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



## 23 Mar 2022 Diag: Don Baldridge



The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.





# **OIL ANALYSIS REPORT**

SAMPLE INFORMATION method limit/base

# Sample Rating Trend ISO

current

history1

historv2

Machine Id 8180369 (S/N 1797) Component

Compressor Fluid KAESER SIGMA (OEM) M-460 (--- GAL)

# DIAGNOSIS

## Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

# Wear

All component wear rates are normal.

# Contamination

There is a high amount of particulates present in the oil.


#### Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA004009	KCP52142	KCP44850
Sample Date		Client Info		17 Jul 2023	17 Nov 2022	23 Mar 2022
Machine Age	hrs	Client Info		4559	3320	1498
Oil Age	hrs	Client Info		1608	1822	1498
Oil Changed		Client Info		Changed	Not Changd	Not Changd
Sample Status				ABNORMAL	ABNORMAL	ATTENTION
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	<1	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	<1	0
Titanium	ppm	ASTM D5185m	>3	<1	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	1	<1
Lead	ppm	ASTM D5185m	>10	0	<1	<1
Copper	ppm	ASTM D5185m	>50	7	5	2
Tin	ppm	ASTM D5185m	>10	0	<1	0
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	90	0	11	71
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		<1	0	0
Magnesium	ppm	ASTM D5185m	100	45	67	99
Calcium	ppm	ASTM D5185m	0	0	2	2
Phosphorus	ppm	ASTM D5185m	0	3	16	7
Zinc	ppm	ASTM D5185m	0	6	9	0
Sulfur	ppm	ASTM D5185m	23500	22340	21305	16828
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1	<1	1
Sodium	ppm	ASTM D5185m		12	22	4
Potassium	ppm	ASTM D5185m	>20	4	3	<1
Water	%	ASTM D6304	>0.05	0.021	0.017	0.014
ppm Water	ppm	ASTM D6304	>500	219.9	178.0	140.6
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		89446	23477	7728
Particles >6µm		ASTM D7647	>1300	<u> </u>	<u> </u>	<b>1</b> 313
Particles >14µm		ASTM D7647	>80	<u> </u>	600	57
Particles >21µm		ASTM D7647	>20	<u> </u>	<b>4</b> 3	17
Particles >38µm		ASTM D7647	>4	1	2	2
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<b>A</b> 24/23/19	▲ 22/21/16	▲ 18/13
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.48	0.35	0.33




# **OIL ANALYSIS REPORT**





VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	LIGHT	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	VLITE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	45	48.4	47.5	45.1
SAMPLE IMAGES		method	limit/base	current	history1	history2
Color						
Bottom						



Contact/Location: Service Manager - BELAGA