




OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id
KAESER SFC 22 T 6576741 (S/N 1008)
 Component
Compressor
 Fluid
KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		KCPA004484	KCP28068	KCP10569
Sample Date	Client Info		26 Jul 2023	13 Jan 2021	26 Jun 2020
Machine Age	hrs	Client Info	21377	8148	4300
Oil Age	hrs	Client Info	0	3848	4300
Oil Changed		Client Info	N/A	Changed	Changed
Sample Status			NORMAL	ABNORMAL	NORMAL

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	0	0	<1
Chromium	ppm	ASTM D5185m >10	0	0	0
Nickel	ppm	ASTM D5185m >3	0	1	0
Titanium	ppm	ASTM D5185m >3	<1	0	0
Silver	ppm	ASTM D5185m >2	0	0	0
Aluminum	ppm	ASTM D5185m >10	0	<1	<1
Lead	ppm	ASTM D5185m >10	0	<1	2
Copper	ppm	ASTM D5185m >50	8	2	10
Tin	ppm	ASTM D5185m >10	0	0	0
Antimony	ppm	ASTM D5185m	---	0	0
Vanadium	ppm	ASTM D5185m	<1	0	0
Cadmium	ppm	ASTM D5185m	<1	0	<1

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 0	0	12	2
Barium	ppm	ASTM D5185m 90	0	67	<1
Molybdenum	ppm	ASTM D5185m 0	0	0	<1
Manganese	ppm	ASTM D5185m	<1	0	0
Magnesium	ppm	ASTM D5185m 100	3	83	17
Calcium	ppm	ASTM D5185m 0	1	<1	3
Phosphorus	ppm	ASTM D5185m 0	4	4	9
Zinc	ppm	ASTM D5185m 0	25	12	32
Sulfur	ppm	ASTM D5185m 23500	21096	19541	14299

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	<1	<1	<1
Sodium	ppm	ASTM D5185m	2	25	9
Potassium	ppm	ASTM D5185m >20	3	7	0
Water	%	ASTM D6304 >0.05	0.005	0.019	0.015
ppm Water	ppm	ASTM D6304 >500	52.7	191.2	150.8






FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		2472	11306	2435
Particles >6µm	ASTM D7647	>1300	784	▲ 4805	669
Particles >14µm	ASTM D7647	>80	42	▲ 306	29
Particles >21µm	ASTM D7647	>20	7	▲ 55	16
Particles >38µm	ASTM D7647	>4	1	2	13
Particles >71µm	ASTM D7647	>3	0	0	12
Oil Cleanliness	ISO 4406 (c)	>--/17/13	18/17/13	▲ 19/15	17/12

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 1.0	0.55	0.311	0.313


OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 45	48.9	46.1	44.6

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KCPA004484 **Received** : 16 Aug 2023
Lab Number : 05926751 **Diagnosed** : 17 Aug 2023
Unique Number : 10606698 **Diagnostician** : Doug Bogart
Test Package : IND 2 (Additional Tests: KF, PrtCount)

HIGH TECH TURNING CO
 16 BRIDGE ST
 WATERTOWN, MA
 US 02472
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: