

PROBLEM SUMMARY

Sample Rating Trend

2/014 Aug/015 Nov/016 Mg-/018 Mg-/019 Aug-/019 Sub-/019 Aug-/019 Sub-/019


WEAR

HS-15 (S/N W0896UFMPTHAA03)

Refrigeration Compressor

NOT GIVEN (150 GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS											
Sample Status				ABNORMAL	NORMAL	ABNORMAL					
Iron	ppm	ASTM D5185m	>8	<u> </u>	6	8					

Customer Id: LAMPAR Sample No.: WC0831596 Lab Number: 05926771 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

23 May 2023 Diag: Jonathan Hester

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the component. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



18 Feb 2023 Diag: Jonathan Hester

VIS DEBRIS



We suspect abnormal contamination may be due to sampling method. We recommend you service the filters on this component. Resample at the next service interval to monitor. All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



20 Nov 2022 Diag: Don Baldridge

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend



HS-15 (S/N W0896UFMPTHAA03)

Refrigeration Compressor

NOT GIVEN (150 GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the component.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	AATION	method	limit/base	current	hioton/1	history2
	MATION		imivoase		history1	
Sample Number		Client Info		WC0831596	WC0796739	WC0765162
Sample Date		Client Info		11 Aug 2023	23 May 2023	18 Feb 2023
Machine Age	hrs	Client Info		0	156063	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>8	<u> </u>	6	8
Chromium	ppm	ASTM D5185m	>2	0	0	0
Nickel	ppm	ASTM D5185m		0	0	0
Titanium	ppm	ASTM D5185m		<1	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>3	0	0	<1
Lead	ppm	ASTM D5185m	>2	0	0	0
Copper	ppm	ASTM D5185m	>8	0	0	0
Tin	ppm	ASTM D5185m	>4	0	0	0
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	0	<1
Magnesium	ppm	ASTM D5185m		<1	0	3
Calcium	ppm	ASTM D5185m		0	0	0
Phosphorus	ppm	ASTM D5185m		1	0	0
Zinc	ppm	ASTM D5185m		0	0	13
Sulfur	ppm	ASTM D5185m		0	43	0
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	<1	0	<1
Sodium	ppm	ASTM D5185m		<1	0	0
Potassium	ppm	ASTM D5185m	>20	1	0	0
Water	%	ASTM D6304	>0.01	0.001	0.003	0.004
ppm Water	ppm	ASTM D6304	>100	12.9	32.2	45.1
FLUID DEGRADA	TION	method	limit/base	current	history1	history2

0.015

Acid Number (AN)


mg KOH/g ASTM D974

0.015

0.015



OIL ANALYSIS REPORT







Certificate L2367

Laboratory Sample No.

Lab Number **Unique Number**

: WC0831596 : 05926771 : 10606718 **Test Package** : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 16 Aug 2023 Diagnosed Diagnostician

: 17 Aug 2023 : Doug Bogart

PARK RAPIDS, MN US 56470 Contact: MICHAEL GRUIS michael.gruis@lambweston.com

T: (218)732-2188

LAMB WESTON/RDO

PO BOX 552

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: (218)732-2175