



# PROBLEM SUMMARY

## Sample Rating Trend




ISO



Area  
**Effluent Treatment Plant**  
 Machine Id  
**Sludge Screw Press #1 Gearbox**  
 Component  
**Gearbox**  
 Fluid  
**MOBIL MOBILGEAR SHC 320 (225 GAL)**

## COMPONENT CONDITION SUMMARY

### ▲ Particle Trend



## RECOMMENDATION

No corrective action is recommended at this time.  
 Resample at the next service interval to monitor.

## PROBLEMATIC TEST RESULTS

Sample Status			<b>ABNORMAL</b>	ABNORMAL	---
Particles >4µm	ASTM D7647	>20000	▲ <b>119204</b>	▲ 138648	---
Particles >6µm	ASTM D7647	>5000	▲ <b>18998</b>	▲ 11728	---
Oil Cleanliness	ISO 4406 (c)	>21/19/16	▲ <b>24/21/14</b>	▲ 24/21/14	---

Customer Id: CASASH  
 Sample No.: WC0776603  
 Lab Number: 05927256  
 Test Package: PLANT



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Doug Bogart +1 (800)237-1369 x4016  
[dougb@wearcheckusa.com](mailto:dougb@wearcheckusa.com)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

*There are no recommended actions for this sample.*

## HISTORICAL DIAGNOSIS

### 26 May 2023 Diag: Wes Davis

ISO



We recommend you service the filters on this component. We recommend an early resample to monitor this condition. All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The water content is negligible. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report





# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area  
**Effluent Treatment Plant**  
 Machine Id  
**Sludge Screw Press #1 Gearbox**  
 Component  
**Gearbox**  
 Fluid  
**MOBIL MOBILGEAR SHC 320 (225 GAL)**

## DIAGNOSIS

### ▲ Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### ▲ Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>WC0776603</b>	WC0776634	---
Sample Date	Client Info			<b>11 Aug 2023</b>	26 May 2023	---
Machine Age	hrs	Client Info		<b>0</b>	0	---
Oil Age	hrs	Client Info		<b>0</b>	0	---
Oil Changed	Client Info			<b>N/A</b>	N/A	---
Sample Status				<b>ABNORMAL</b>	ABNORMAL	---

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>200	<b>22</b>	17	---
Chromium	ppm	ASTM D5185m	>15	<b>&lt;1</b>	0	---
Nickel	ppm	ASTM D5185m	>15	<b>0</b>	0	---
Titanium	ppm	ASTM D5185m		<b>&lt;1</b>	0	---
Silver	ppm	ASTM D5185m		<b>0</b>	0	---
Aluminum	ppm	ASTM D5185m	>25	<b>&lt;1</b>	0	---
Lead	ppm	ASTM D5185m	>100	<b>&lt;1</b>	0	---
Copper	ppm	ASTM D5185m	>200	<b>&lt;1</b>	0	---
Tin	ppm	ASTM D5185m	>25	<b>0</b>	0	---
Vanadium	ppm	ASTM D5185m		<b>&lt;1</b>	0	---
Cadmium	ppm	ASTM D5185m		<b>0</b>	0	---

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		<b>9</b>	9	---
Barium	ppm	ASTM D5185m		<b>0</b>	0	---
Molybdenum	ppm	ASTM D5185m		<b>18</b>	14	---
Manganese	ppm	ASTM D5185m		<b>&lt;1</b>	<1	---
Magnesium	ppm	ASTM D5185m		<b>3</b>	2	---
Calcium	ppm	ASTM D5185m		<b>4</b>	2	---
Phosphorus	ppm	ASTM D5185m		<b>516</b>	527	---
Zinc	ppm	ASTM D5185m		<b>10</b>	0	---
Sulfur	ppm	ASTM D5185m		<b>4110</b>	4008	---






CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	<b>19</b>	21	---
Sodium	ppm	ASTM D5185m		<b>1</b>	0	---
Potassium	ppm	ASTM D5185m	>20	<b>3</b>	1	---
Water	%	ASTM D6304	>0.2	<b>0.005</b>	0.016	---
ppm Water	ppm	ASTM D6304	>2000	<b>59.6</b>	165.9	---

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>20000	▲ <b>119204</b>	▲ 138648	---
Particles >6µm		ASTM D7647	>5000	▲ <b>18998</b>	▲ 11728	---
Particles >14µm		ASTM D7647	>640	<b>91</b>	94	---
Particles >21µm		ASTM D7647	>160	<b>17</b>	14	---
Particles >38µm		ASTM D7647	>40	<b>1</b>	1	---
Particles >71µm		ASTM D7647	>10	<b>1</b>	0	---
Oil Cleanliness		ISO 4406 (c)	>21/19/16	▲ <b>24/21/14</b>	▲ 24/21/14	---

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		<b>1.00</b>	1.03	---




# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	---
Debris	scalar	*Visual	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.2	NEG	---
Free Water	scalar	*Visual		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 320	310	314	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0776603 **Received** : 17 Aug 2023  
**Lab Number** : 05927256 **Diagnosed** : 18 Aug 2023  
**Unique Number** : 10607203 **Diagnostician** : Doug Bogart  
**Test Package** : PLANT

CASCADES CONTAINERBOARD PACKAGING - BEARPACK PROJECT  
 10026 OLD RIDGE ROAD  
 ASHLAND, VA  
 US 23005  
 Contact: MARC-ANDRE HUBERT  
 marc-andre\_hubert@cascades.com  
 T:  
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)