

PROBLEM SUMMARY

Sample Rating Trend

WEAR

Machine Id


KAESER SFC 22 7011176 (S/N 1039)

Component

Compressor

KAESER SIGMA (OEM) FG-460 (--- GAL)

COMPONENT CONDITION SUMMARY





RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS										
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL				
Aluminum	ppm	ASTM D5185m	>10	<u></u> ▲ 51	1 3	<u>^</u> 23				
Particles >6μm		ASTM D7647	>1300	1597	<u> </u>	▲ 3995				
Particles >14µm		ASTM D7647	>80	<u>^</u> 201	<u>▲</u> 1367	▲ 174				
Particles >21µm		ASTM D7647	>20	60	△ 356	▲ 33				
Oil Cleanliness		ISO 4406 (c)	>/17/13	19/18/15	<u>^</u> 22/21/18	<u>\(21/19/15</u>				

Customer Id: LEPDENCO Sample No.: KCPA004850 Lab Number: 05927275 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

17 Feb 2023 Diag: Don Baldridge

WEAR



Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor. The aluminum level is abnormal. All other component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.



09 Aug 2022 Diag: Don Baldridge

WEAR



Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor. The copper level is abnormal. All other component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.



19 Jan 2022 Diag: Don Baldridge

VIS DEBRIS



No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend



KAESER SFC 22 7011176 (S/N 1039)

Compressor

KAESER SIGMA (OEM) FG-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

The aluminum level is abnormal. All other component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Jul2020	Jul2021 Jan2022	Aug2022 Feb2023	Aug2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA004850	KCP55397	KCP44064
Sample Date		Client Info		04 Aug 2023	17 Feb 2023	09 Aug 2022
Machine Age	hrs	Client Info		23350	19843	17175
Oil Age	hrs	Client Info		0	2700	3046
Oil Changed		Client Info		N/A	Changed	Changed
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	5	2	4
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	<1	0
Titanium	ppm	ASTM D5185m	>3	<1	0	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m	>10	<u> </u>	<u>13</u>	<u>▲</u> 23
Lead	ppm	ASTM D5185m	>10	<1	0	0
Copper	ppm	ASTM D5185m	>50	3	7	3
Tin	ppm	ASTM D5185m	>10	0	<1	<1
Antimony	ppm	ASTM D5185m				
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	2	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	<1	0
Magnesium	ppm	ASTM D5185m		6	3	0
Calcium	ppm	ASTM D5185m		2	0	0
Phosphorus	ppm	ASTM D5185m	500	328	388	385
Zinc	ppm	ASTM D5185m		107	189	183
Sulfur	ppm	ASTM D5185m		1966	1583	1749
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	0	0
Sodium	ppm	ASTM D5185m		4	0	<1
Potassium	ppm	ASTM D5185m	>20	4	2	0
Water	%	ASTM D6304	>0.05	0.003	0.001	0.004
ppm Water	ppm	ASTM D6304	>500	36.5	8.4	45.8
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647		3815	37310	12591
Particles >6µm		ASTM D7647	>1300	<u> </u>	<u>14364</u>	△ 3995
Particles >14μm		ASTM D7647	>80	<u>^</u> 201	<u>▲</u> 1367	<u> </u>
Particles >21µm		ASTM D7647	>20	<u>^</u> 60	△ 356	△ 33
Particles >38μm		ASTM D7647	>4	2	<u> 11</u>	1
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u> </u>	<u>22/21/18</u>	<u>^</u> 21/19/15
FLUID DEGRADA	TION	method	limit/base	current	history1	history2



OIL ANALYSIS REPORT



To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: