


OIL ANALYSIS REPORT

Sample Rating Trend







Machine Id
C-10
Component
Refrigeration Compressor
Fluid
USPI ALT-68 SC (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

w2014 Apr2015 Jan2016 New2016 Apr2020 Feb2021 Oct2021 Jun2022 Oct2022 Aug/202						
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USP0000602	USP249256	USP247903
Sample Date		Client Info		16 Aug 2023	16 May 2023	05 Dec 2022
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>8	0	0	0
Chromium	ppm	ASTM D5185m	>2	0	0	0
Nickel	ppm	ASTM D5185m		0	0	0
Titanium	ppm	ASTM D5185m		<1	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>3	<1	1	0
Lead	ppm	ASTM D5185m	>2	0	0	0
Copper	ppm	ASTM D5185m	>8	0	0	0
Tin	ppm	ASTM D5185m	>4	0	0	0
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	0	0
Magnesium	ppm	ASTM D5185m		0	0	<1
Calcium	ppm	ASTM D5185m		0	0	0
Phosphorus	ppm	ASTM D5185m		0	<1	0
Zinc	ppm	ASTM D5185m		0	0	1
Sulfur	ppm	ASTM D5185m	50	<1	0	0
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	1	<1	2
Sodium	ppm	ASTM D5185m		<1	0	<1
Potassium	ppm	ASTM D5185m	>20	1	0	0
Water	%	ASTM D6304	>0.01	0.005	0.006	0.007
ppm Water	ppm	ASTM D6304	>100	59.9	65.7	70.2
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	413	1432	828
Particles >6μm		ASTM D7647	>2500	118	373	185
Particles >14µm		ASTM D7647	>320	10	37	8
Particles >21µm		ASTM D7647	>80	4	9	2
Particles >38µm		ASTM D7647	>20	1	0	0
Particles >71µm		ASTM D7647	>4	1	0	0
Oil Cleanliness		ISO 4406 (c)	>20/18/15	16/14/10	18/16/12	17/15/10
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
A si al Niversala a v. (ANI)	I/OII/-	ACTM DOZA	0.005	0.015	0.010	0.014

Acid Number (AN)

0.013

0.015

mg KOH/g ASTM D974 0.005

0.014



OIL ANALYSIS REPORT





Certificate L2367

Sample No. Lab Number **Unique Number** Test Package

: USP0000602 : 05927297 : 10607244 : IND 2

Received : 17 Aug 2023 Diagnosed : 18 Aug 2023 : Doug Bogart Diagnostician

12730H WESTPORT RD LOUISVILLE, KY US 40245

Contact: SCOTT CASTILLO

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: