


OIL ANALYSIS REPORT

ULTRA COOLANT [148284] Machine Id CBV319368 - DUBOIS CHEMICALS

Component

Compressor





DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil


Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Sep2017 Jan2	019 Jul2019 Jan2020 Jul2	020 Jan2021 Jul2021 Jul2022 Jan2	023 Aug2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UCH05927377	UCH05762166	UCH05615852
Sample Date		Client Info		01 Aug 2023	27 Jan 2023	28 Jul 2022
Machine Age	hrs	Client Info		1969	17282	555
Oil Age	hrs	Client Info		1414	0	0
Oil Changed		Client Info		Changed	Changed	Changed
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	8	4	18
Chromium	ppm	ASTM D5185m	>10	<1	0	<1
Nickel	ppm	ASTM D5185m		0	0	5
Titanium	ppm	ASTM D5185m		<1	<1	0
Silver	ppm	ASTM D5185m		0	0	<1
Aluminum	ppm	ASTM D5185m	>25	1	0	<1
Lead	ppm	ASTM D5185m	>25	<1	0	0
Copper	ppm	ASTM D5185m		9	15	11
Tin	ppm	ASTM D5185m	>15	<1	<1	<1
Antimony	ppm	ASTM D5185m	- 10			
Vanadium		ASTM D5185m		0	0	<1
Cadmium	ppm	ASTM D5185m		0	0	<1
	ppm				-	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	5
Barium	ppm	ASTM D5185m	500	292	572	167
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		<1	0	<1
Magnesium	ppm	ASTM D5185m	0	4	<1	2
Calcium	ppm	ASTM D5185m	0	10	4	8
Phosphorus	ppm	ASTM D5185m	20	3	7	8
Zinc	ppm	ASTM D5185m	0	271	198	64
Sulfur	ppm	ASTM D5185m	200	397	277	341
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	3	3	5
Sodium	ppm	ASTM D5185m		49	31	52
Potassium	ppm	ASTM D5185m	>20	2	2	4
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.80	0.67	0.35
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	MODER	MODER
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	KEWIEGDESPO	
TICE WALE	Scalai	Visual		INEG	IVE MIDODEOLO	1 WHE OF LIVIOL



OIL ANALYSIS REPORT










Ferrous Alloys 12

GRAPHS











Certificate L2367

Laboratory Sample No. Test Package : IND 2

Lab Number **Unique Number**

: UCH05927377 : 05927377 : 10607324

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 17 Aug 2023 Diagnosed Diagnostician : Jonathan Hester

: 21 Aug 2023

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

A-L-L EQUIPMENT INC

204 38TH ST MOLINE, IL US 61265

Contact: KEVIN DESPOT kevind@a-l-lequipment.com

T: (815)877-7000 F: (309)762-9950

Contact/Location: KEVIN DESPOT - UCALLMOL