

OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



Machine Id KAESER AS 20T 5714185 (S/N 1159)

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Feb 2019	Jul2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCP48196D	KCP11129	
Sample Date		Client Info		25 Jul 2023	09 Feb 2019	
Machine Age	hrs	Client Info		10753	2729	
Oil Age	hrs	Client Info		1000	2729	
Oil Changed		Client Info		Changed	Changed	
Sample Status				NORMAL	ATTENTION	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	1	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	<1	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	0	0	
Lead	ppm	ASTM D5185m	>10	0	0	
Copper	ppm	ASTM D5185m	>50	21	7	
Tin	ppm	ASTM D5185m	>10	0	0	
Antimony	ppm	ASTM D5185m	7 10		0	
Vanadium	ppm	ASTM D5185m		<1	0	
Cadmium	ppm	ASTM D5185m		0	0	
	ррпп			· ·		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	
Barium	ppm	ASTM D5185m	90	0	0	
Molybdenum	ppm	ASTM D5185m	0	0	<1	
Manganese	ppm	ASTM D5185m		0	<1	
Magnesium	ppm	ASTM D5185m	100	10	40	
Calcium	ppm	ASTM D5185m	0	2	<1	
Phosphorus	ppm	ASTM D5185m	0	10	1	
Zinc	ppm	ASTM D5185m	0	49	11	
Sulfur	ppm	ASTM D5185m	23500	22531	17114	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	
Sodium	ppm	ASTM D5185m		2	14	
Potassium	ppm	ASTM D5185m	>20	1	<1	
Water	%	ASTM D6304	>0.05	0.008	0.011	
ppm Water	ppm	ASTM D6304	>500	86.7	110	
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		4241	4667	
Particles >6µm		ASTM D7647	>1300	1183	1 305	
Particles >14µm		ASTM D7647	>80	67	76	
Particles >21µm		ASTM D7647	>20	16	21	
Particles >38µm		ASTM D7647	>4	1	2	
Particles >71µm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	19/17/13	▲ 18/13	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2



OIL ANALYSIS REPORT





Certificate L2367

Sample No. Lab Number **Unique Number**

: 05927840

: KCP48196D

Received Diagnosed : 10607787

: 17 Aug 2023 : 21 Aug 2023 Diagnostician : Don Baldridge

Test Package : IND 2 (Additional Tests: KF, PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

531 ROUTE 38 W MAPLE SHADE, NJ

US 08057

Contact: Service Manager

T: F: