

OIL ANALYSIS REPORT

Sample Rating Trend



FES TYSCEN HS-21 (S/N Z0265)

Refrigeration Compressor

USPI ALT-68 SC (--- GAL)

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

-2013 Feb2015 Jud016 Oc2017 Med2019 Med2021 Sep2022						
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USP239782	USP239780	USP239779
Sample Date		Client Info		10 Aug 2023	25 May 2023	10 Mar 2023
Machine Age	hrs	Client Info		69554	68111	66746
Oil Age	hrs	Client Info		69554	68111	66746
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	ATTENTION	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>8	0	0	0
Chromium	ppm	ASTM D5185m	>2	0	0	0
Nickel	ppm	ASTM D5185m		0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>3	0	0	<1
Lead	ppm	ASTM D5185m	>2	0	0	0
Copper	ppm	ASTM D5185m	>8	0	0	0
Tin	ppm	ASTM D5185m	>4	0	0	0
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m		0	0	0
Calcium	ppm	ASTM D5185m		0	<1	0
Phosphorus	ppm	ASTM D5185m		<1	0	0
Zinc	ppm	ASTM D5185m		0	0	0
Sulfur	ppm	ASTM D5185m	50	12	0	0
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	1	1	2
Sodium	ppm	ASTM D5185m		0	0	0
Potassium	ppm	ASTM D5185m	>20	<1	<1	0
Water	%	ASTM D6304	>0.01	0.003	0.007	0.006
ppm Water	ppm	ASTM D6304	>100	30.9	78.8	65.3
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	3007	<u> </u>	▲ 18136
Particles >6µm		ASTM D7647	>2500	763	<u>^</u> 2965	<u>△</u> 5931
Particles >14µm		ASTM D7647	>320	57	44	230
Particles >21µm		ASTM D7647	>80	14	5	22
Particles >38µm		ASTM D7647	>20	0	0	1
Particles >71µm		ASTM D7647	>4	0	0	0
Oil Cleanliness		ISO 4406 (c)	>20/18/15	19/17/13	<u>\$\lambda\$\$ 21/19/13</u>	<u>\$\text{21/20/15}\$</u>
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974	0.005	0.015	0.015	0.013

Contact/Location: PAT HART - TYSCEN01



OIL ANALYSIS REPORT







Certificate L2367

Unique Number

Sample No. Lab Number

: 05927891 : 10607838 Test Package : IND 2

: USP239782 Received : 17 Aug 2023 : 18 Aug 2023 Diagnosed

: Doug Bogart

Diagnostician

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) PO BOX 1960 CENTER, TX US 75935

Contact: PAT HART

T: (936)598-2723 F: (479)757-6892

Contact/Location: PAT HART - TYSCEN01