PROBLEM SUMMARY

Area
HIGHLAND [600380482]
Machine Id
04WEA80811
Component
Hydraulic System
Fluid
SHELL TELLUS ARTIC 32 (--- LTR)

Sample Rating Trend



ISO

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We recommend you service the filters on this component. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status				**ABNORMAL**	NORMAL	MARGINAL
Particles >4µm		ASTM D7647	>20000	▲ **50320**	295	4253
Oil Cleanliness		ISO 4406 (c)	>21/18/15	▲ **23/18/11**	15/12/9	19/17/13

Customer Id: NORHIG
Sample No.: NX05928149
Lab Number: 05928149
Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data:
Don Baldridge +1
don.b505@comcast.net

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.

HISTORICAL DIAGNOSIS

05 Apr 2022 Diag: Don Baldridge

NORMAL

Resample at the next service interval to monitor.All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report

20 Oct 2021 Diag: Angela Borella

WEAR

No corrective action is recommended at this time. Resample at the next service interval to monitor.The iron level is marginal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report

24 Jun 2021 Diag: Doug Bogart

WEAR

No corrective action is recommended at this time. Resample at the next service interval to monitor.The iron level is marginal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report

OIL ANALYSIS REPORT

Sample Rating Trend



ISO

Area
HIGHLAND [600380482]
Machine Id
04WEA80811
Component
Hydraulic System
Fluid
SHELL TELLUS ARTIC 32 (--- LTR)

DIAGNOSIS

Recommendation
We recommend you service the filters on this component. Resample at the next service interval to monitor.

Wear
All component wear rates are normal.

Contamination
There is a high amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number		Client Info		**NX05928149**	NX05602797	NX05428503
Sample Date		Client Info		**08 Mar 2023**	05 Apr 2022	20 Oct 2021
Machine Age	mths	Client Info		**0**	0	0
Oil Age	mths	Client Info		**0**	0	0
Oil Changed		Client Info		**N/A**	N/A	N/A
Sample Status				**ABNORMAL**	NORMAL	MARGINAL

WEAR METALS		method	limit/base	current	history1	history2
PQ		ASTM D8184		**19**	16	21
Iron	ppm	ASTM D5185m	>20	**9**	0	▲ 25
Chromium	ppm	ASTM D5185m	>20	**<1**	0	<1
Nickel	ppm	ASTM D5185m	>20	**0**	<1	0
Titanium	ppm	ASTM D5185m		**0**	0	0
Silver	ppm	ASTM D5185m		**0**	<1	<1
Aluminum	ppm	ASTM D5185m	>20	**<1**	0	0
Lead	ppm	ASTM D5185m	>20	**1**	0	4
Copper	ppm	ASTM D5185m	>20	**<1**	0	<1
Tin	ppm	ASTM D5185m	>20	**0**	<1	<1
Antimony	ppm	ASTM D5185m		**---**	---	0
Vanadium	ppm	ASTM D5185m		**0**	0	0
Cadmium	ppm	ASTM D5185m		**0**	<1	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	5	**0**	<1	<1
Barium	ppm	ASTM D5185m	0	**0**	0	0
Molybdenum	ppm	ASTM D5185m	0	**0**	0	0
Manganese	ppm	ASTM D5185m	0	**0**	0	<1
Magnesium	ppm	ASTM D5185m	0	**<1**	0	0
Calcium	ppm	ASTM D5185m	5	**<1**	0	3
Phosphorus	ppm	ASTM D5185m	600	**589**	616	554
Zinc	ppm	ASTM D5185m	50	**63**	56	90
Sulfur	ppm	ASTM D5185m	900	**587**	559	668

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	**1**	0	3
Sodium	ppm	ASTM D5185m		**0**	0	0
Potassium	ppm	ASTM D5185m	>20	**0**	0	0
Water	%	ASTM D6304	>0.05	**0.013**	0.008	0.007
ppm Water	ppm	ASTM D6304	>500	**137.1**	84.4	74.8

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>20000	▲ **50320**	295	4253
Particles >6µm		ASTM D7647	>2500	**1444**	38	823
Particles >14µm		ASTM D7647	>320	**20**	4	80
Particles >21µm		ASTM D7647	>80	**3**	2	21
Particles >38µm		ASTM D7647	>20	**1**	0	3
Particles >71µm		ASTM D7647	>4	**0**	0	0
Oil Cleanliness		ISO 4406 (c)	>21/18/15	▲ **23/18/11**	15/12/9	19/17/13

OIL ANALYSIS REPORT

Particle Trend



Water



PQ



Water



Viscosity @ 40°C



FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.20	**0.13**	0.07	0.131

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Precipitate	scalar	*Visual	NONE	**NONE**	NONE	NONE
Silt	scalar	*Visual	NONE	**NONE**	NONE	NONE
Debris	scalar	*Visual	NONE	**NONE**	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	**NONE**	NONE	NONE
Appearance	scalar	*Visual	NORML	**NORML**	NORML	NORML
Odor	scalar	*Visual	NORML	**NORML**	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	**NEG**	NEG	NEG
Free Water	scalar	*Visual		**NEG**	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	33.6	**32.6**	31.5	31.8

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					



GRAPHS

Ferrous Alloys



Non-ferrous Metals



Viscosity @ 40°C



Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : NX05928149 **Received** : 18 Aug 2023
Lab Number : 05928149 **Diagnosed** : 21 Aug 2023
Unique Number : 10608096 **Diagnostician** : Don Baldridge
Test Package : IND 2 (Additional Tests: KF, PQ)

To discuss this sample report, contact Customer Service at 1-800-237-1369.
** - Denotes test methods that are outside of the ISO 17025 scope of accreditation.*
Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

NORDEX USA - HIGHLAND & HIGHLAND NORTH
300 SOUTH WACKER DRIVE, SUITE 1500
CHICAGO, IL
US 60606
Contact: Robert Warner
rwarner@everpower.com
T: x:
F: x: