




# PROBLEM SUMMARY

Sample Rating Trend



## VISUAL METAL



Area  
**HIGHLAND [600380489]**  
 Machine Id  
**11WEA80818**  
 Component  
**Wind Turbine Gearbox**  
 Fluid  
**MOBIL XMP 320 (--- LTR)**

### COMPONENT CONDITION SUMMARY

No relevant graphs to display


### RECOMMENDATION

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. We were unable to perform a particle count due to metal particles present in this sample.

### PROBLEMATIC TEST RESULTS

Sample Status				<b>ABNORMAL</b>	ABNORMAL	NORMAL
White Metal	scalar	*Visual	NONE	<b>▲ MODER</b>	NONE	NONE

**Customer Id:** NORHIG  
**Sample No.:** NX05928201  
**Lab Number:** 05928201  
**Test Package:** IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Don Baldrige +1  
[don.b505@comcast.net](mailto:don.b505@comcast.net)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Inspect Wear Source	---	---	?	We advise that you inspect for the source(s) of wear.
Change Filter	---	---	?	We recommend you service the filters on this component if applicable.
Alert	---	---	?	We were unable to perform a particle count due to metal particles present in this sample.

## HISTORICAL DIAGNOSIS

### 08 Nov 2022 Diag: Angela Borella

ISO



No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 24 May 2022 Diag: Don Baldrige

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 01 Feb 2022 Diag: Doug Bogart

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





# OIL ANALYSIS REPORT

Sample Rating Trend



**VISUAL METAL**



Area  
**HIGHLAND [600380489]**  
 Machine Id  
**11WEA80818**  
 Component  
**Wind Turbine Gearbox**  
 Fluid  
**MOBIL XMP 320 (--- LTR)**

## DIAGNOSIS

### Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. We were unable to perform a particle count due to metal particles present in this sample.

### Wear

Moderate concentration of visible metal present. All component wear rates are normal.

### Contamination

No other contaminants were detected in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>NX05928201</b>	NX05700263	NX05602744
Sample Date	Client Info	<b>11 May 2023</b>	08 Nov 2022	24 May 2022
Machine Age	mths	Client Info	0	0
Oil Age	mths	Client Info	0	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>ABNORMAL</b>	ABNORMAL	NORMAL

## WEAR METALS

method	limit/base	current	history1	history2		
PQ	ASTM D8184	>80	<b>14</b>	21	19	
Iron	ppm	ASTM D5185m	>150	<b>45</b>	106	56
Chromium	ppm	ASTM D5185m	>5	<b>0</b>	<1	0
Nickel	ppm	ASTM D5185m	>10	<b>0</b>	0	<1
Titanium	ppm	ASTM D5185m	>10	<b>0</b>	0	0
Silver	ppm	ASTM D5185m		<b>0</b>	0	<1
Aluminum	ppm	ASTM D5185m	>10	<b>0</b>	<1	<1
Lead	ppm	ASTM D5185m	>20	<b>0</b>	0	0
Copper	ppm	ASTM D5185m	>50	<b>2</b>	2	1
Tin	ppm	ASTM D5185m	>10	<b>0</b>	0	<1
Antimony	ppm	ASTM D5185m	>5	<b>---</b>	---	---
Vanadium	ppm	ASTM D5185m		<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m		<b>0</b>	0	0

## ADDITIVES

method	limit/base	current	history1	history2		
Boron	ppm	ASTM D5185m		<b>0</b>	0	<1
Barium	ppm	ASTM D5185m		<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m		<b>1</b>	0	0
Manganese	ppm	ASTM D5185m		<b>&lt;1</b>	2	<1
Magnesium	ppm	ASTM D5185m		<b>&lt;1</b>	0	0
Calcium	ppm	ASTM D5185m		<b>4</b>	0	0
Phosphorus	ppm	ASTM D5185m	315	<b>391</b>	359	240
Zinc	ppm	ASTM D5185m		<b>9</b>	20	15
Sulfur	ppm	ASTM D5185m		<b>14916</b>	14313	9220

## CONTAMINANTS





method	limit/base	current	history1	history2		
Silicon	ppm	ASTM D5185m	>50	<b>1</b>	<1	0
Sodium	ppm	ASTM D5185m	>20	<b>0</b>	0	0
Potassium	ppm	ASTM D5185m	>20	<b>&lt;1</b>	0	0
Water	%	ASTM D6304	>0.05	<b>0.014</b>	0.014	0.021
ppm Water	ppm	ASTM D6304	>500	<b>140.3</b>	148.0	213.9

## FLUID CLEANLINESS

method	limit/base	current	history1	history2		
Particles >4µm	ASTM D7647			<b>---</b>	128232	4629
Particles >6µm	ASTM D7647	>2500		<b>---</b>	▲ 5212	622
Particles >14µm	ASTM D7647	>320		<b>---</b>	16	31
Particles >21µm	ASTM D7647	>80		<b>---</b>	4	8
Particles >38µm	ASTM D7647	>20		<b>---</b>	0	3
Particles >71µm	ASTM D7647	>4		<b>---</b>	0	2
Oil Cleanliness	ISO 4406 (c)	>--/18/15		<b>---</b>	▲ 24/20/11	19/16/12



# OIL ANALYSIS REPORT



FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		<b>0.96</b>	1.11	1.08


VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	<b>▲ MODER</b>	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Silt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Debris	scalar	*Visual	NONE	<b>LIGHT</b>	LIGHT	LIGHT
Sand/Dirt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	<b>NEG</b>	NEG	NEG
Free Water	scalar	*Visual		<b>NEG</b>	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	320	<b>322</b>	329	325





SAMPLE IMAGES		method	limit/base	current	history1	history2
---------------	--	--------	------------	---------	----------	----------

Color

Bottom



## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : NX05928201  
**Lab Number** : 05928201  
**Unique Number** : 10608148  
**Test Package** : IND 2 ( Additional Tests: KF, PQ, PrtCount )

**NORDEX USA - HIGHLAND & HIGHLAND NORTH**  
 300 SOUTH WACKER DRIVE, SUITE 1500  
 CHICAGO, IL  
 US 60606  
 Contact: Robert Warner  
 rwarner@everpower.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: x:

F: x: