




OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



Area
HIGHLAND [600380481]
 Machine Id
03WEA80810
 Component
Wind Turbine Gearbox
 Fluid
MOBIL XMP 320 (--- LTR)



DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		NX05928219	NX05766524	NX05700259
Sample Date	Client Info		22 Mar 2023	21 Dec 2022	29 Sep 2022
Machine Age	mths	Client Info	0	0	0
Oil Age	mths	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			NORMAL	ABNORMAL	NORMAL

WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184	>80	15	18	8
Iron	ppm	ASTM D5185m	>150	134	119
Chromium	ppm	ASTM D5185m	>5	2	2
Nickel	ppm	ASTM D5185m	>10	0	<1
Titanium	ppm	ASTM D5185m	>10	0	0
Silver	ppm	ASTM D5185m		0	0
Aluminum	ppm	ASTM D5185m	>10	0	<1
Lead	ppm	ASTM D5185m	>20	0	<1
Copper	ppm	ASTM D5185m	>50	1	1
Tin	ppm	ASTM D5185m	>10	0	<1
Vanadium	ppm	ASTM D5185m		0	0
Cadmium	ppm	ASTM D5185m		0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0
Barium	ppm	ASTM D5185m		0	0
Molybdenum	ppm	ASTM D5185m		2	<1
Manganese	ppm	ASTM D5185m		1	2
Magnesium	ppm	ASTM D5185m		0	<1
Calcium	ppm	ASTM D5185m		2	<1
Phosphorus	ppm	ASTM D5185m	315	363	341
Zinc	ppm	ASTM D5185m		24	27
Sulfur	ppm	ASTM D5185m		13652	12766

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	<1	<1
Sodium	ppm	ASTM D5185m	>20	0	1
Potassium	ppm	ASTM D5185m	>20	<1	<1
Water	%	ASTM D6304	>0.05	0.014	0.010
ppm Water	ppm	ASTM D6304	>500	140.9	106.8

FLUID CLEANLINESS






	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		2207	116614	952
Particles >6µm	ASTM D7647	>2500	128	▲ 21099	84
Particles >14µm	ASTM D7647	>320	24	41	9
Particles >21µm	ASTM D7647	>80	8	3	3
Particles >38µm	ASTM D7647	>20	1	0	1
Particles >71µm	ASTM D7647	>4	0	0	0
Oil Cleanliness	ISO 4406 (c)	>--/18/15	18/14/12	▲ 24/22/13	17/14/10

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		1.15	1.23




OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D445	320	330	327	329

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : NX05928219 **Received** : 18 Aug 2023
Lab Number : **05928219** **Diagnosed** : 21 Aug 2023
Unique Number : 10608166 **Diagnostician** : Don Baldrige

NORDEX USA - HIGHLAND & HIGHLAND NORTH
 300 SOUTH WACKER DRIVE, SUITE 1500
 CHICAGO, IL
 US 60606

Test Package : IND 2 (Additional Tests: KF, PQ, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact: Robert Warner
 rwarner@everpower.com

T: x:
 F: x: