

PROBLEM SUMMARY

Sample Rating Trend


DIRT

South Plant-Fermentation A1760F

Component


Gearbox


HIGH PERFORMANCE LUBRICANTS TURBINE LIFE 320 (20 GAL)





COMPONENT CONDITION SUMMARY





RECOMMENDATION

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

PROBLEMATIC 1	EST RE	SULTS				
Sample Status				ABNORMAL	NORMAL	SEVERE
Silicon	ppm	ASTM D5185m	>50	<u></u> ▲ 86	26	11
Particles >4µm		ASTM D7647	>5000	<u> </u>	1334	183348
Particles >6µm		ASTM D7647	>1300	13504	186	82154
Particles >14µm		ASTM D7647	>160	758	8	1592
Particles >21µm		ASTM D7647	>40	199	2	544
Oil Cleanliness		ISO 4406 (c)	>19/17/14	<u> </u>	18/15/10	25/24/18

Customer Id: AJIEDD **Sample No.:** WC0786802 Lab Number: 05928250 Test Package: PLANT



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter			?	We recommend you service the filters on this component if applicable.

HISTORICAL DIAGNOSIS

02 Feb 2023 Diag: Don Baldridge

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



01 Dec 2022 Diag: Angela Borella

ISO



We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample at the next service interval to monitor. An increase in the iron level is noted. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid.

21 Mar 2022 Diag: Jonathan Hester

WEAR



No corrective action is recommended at this time. Resample at the next service interval to monitor. An increase in the iron level is noted. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. Additive levels indicate the addition of a different brand, or type of oil. The AN level is acceptable for this fluid.





OIL ANALYSIS REPORT

Sample Rating Trend

DIRT

South Plant-Fermentation Machine Id A1760F

Component

Gearbox

HIGH PERFORMANCE LUBRICANTS TURBINE LIFE 320 (20 GAL)

▲ Recommendation

DIAGNOSIS

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil. Elemental level of silicon (Si) above normal.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

INE LIFE 320 (20	J GAL)	lug2018 Jan	2019 Apr2019 Oct201	9 May2020 Mar2021 Dec20	22 Aug202:	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0786802	WC0765993	WC0723613
Sample Date		Client Info		15 Aug 2023	02 Feb 2023	01 Dec 2022
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	NORMAL	SEVERE
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>200	24	46	<u></u> 118
Chromium	ppm	ASTM D5185m	>10	0	0	<1
Nickel	ppm	ASTM D5185m	>10	<1	0	2
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	<1	0
Aluminum	ppm	ASTM D5185m	>25	0	2	1
Lead	ppm	ASTM D5185m	>50	0	0	0
Copper	ppm	ASTM D5185m	>200	<1	<1	<1
Tin	ppm	ASTM D5185m	>10	0	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		<1	2	0
Barium	ppm	ASTM D5185m		0	<1	0
Molybdenum	ppm	ASTM D5185m		<1	0	<1
Manganese	ppm	ASTM D5185m		0	<1	<1
Magnesium	ppm	ASTM D5185m		0	<1	2
Calcium	ppm	ASTM D5185m	200	0	2	0
Phosphorus	ppm	ASTM D5185m		96	273	111
Zinc	ppm	ASTM D5185m		18	33	14
Sulfur	ppm	ASTM D5185m	19000	28558	29139	22148
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	▲ 86	26	11
Sodium	ppm	ASTM D5185m		0	1	0
Potassium	ppm	ASTM D5185m	>20	0	0	0
Water	%	ASTM D6304	>0.2	0.009	0.009	0.012
ppm Water	ppm	ASTM D6304	>2000	97.3	90.8	121.1
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647	>5000	<u> </u>	1334	183348
Particles >6µm		ASTM D7647	>1300	<u> </u>	186	82154
i articics >oμin			100	and the second s	_	
•		ASTM D7647	>160	<u> </u>	8	1592
Particles >14μm		ASTM D7647 ASTM D7647		▲ 758 ▲ 199	8	1592 544
Particles >14μm Particles >21μm				▲ 199 5		
Particles >14µm Particles >21µm Particles >38µm Particles >71µm		ASTM D7647	>40 >10	<u> </u>	2	5 44
Particles >14µm Particles >21µm Particles >38µm		ASTM D7647 ASTM D7647	>40 >10	▲ 199 5	2	544▲ 23
Particles >14µm Particles >21µm Particles >38µm Particles >71µm	ATION	ASTM D7647 ASTM D7647 ASTM D7647	>40 >10 >3	▲ 199 5 0	2 0 0	544▲ 231



OIL ANALYSIS REPORT







Certificate L2367

Lab Number **Unique Number**

: 05928250 : 10608197 Test Package : PLANT

: 21 Aug 2023 Diagnosed

Diagnostician : Doug Bogart

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) EDDYVILLE, IA US 52553

Contact: Alan Brittain brittaina@ajiusa.com T: (641)295-0086

F: