




PROBLEM SUMMARY


Sample Rating Trend



Machine Id
BUSCH VM3 / VP-2 (S/N 003-136684)
 Component
Pump
 Fluid
USPI VAC 100 (--- GAL)

COMPONENT CONDITION SUMMARY

▲ Aluminum (ppm)



RECOMMENDATION

No corrective action is recommended at this time.
 Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status				MARGINAL	ABNORMAL	NORMAL
Aluminum	ppm	ASTM D5185m	>7	▲ 18	▲ 23	2

Customer Id: IBPDAK01
 Sample No.: USPM29247
 Lab Number: 05928266
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Doug Bogart +1 (800)237-1369 x4016
dougb@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

11 May 2023 Diag: Doug Bogart

WEAR



No corrective action is recommended at this time. We recommend an early resample to monitor this condition. The aluminum level is abnormal. All other component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



26 Jan 2023 Diag: Jonathan Hester

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



03 Oct 2022 Diag: Doug Bogart

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



WEAR



Machine Id
BUSCH VM3 / VP-2 (S/N 003-136684)
 Component
Pump
 Fluid
USPI VAC 100 (--- GAL)

DIAGNOSIS

▲ Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

▲ Wear

The aluminum level is abnormal. All other component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	USPM29247	USPM28915	USPM26253
Sample Date	Client Info	19 Aug 2023	11 May 2023	26 Jan 2023
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		MARGINAL	ABNORMAL	NORMAL

WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >90	<1	<1
Chromium	ppm	ASTM D5185m >5	0	0
Nickel	ppm	ASTM D5185m >5	0	<1
Titanium	ppm	ASTM D5185m >3	0	0
Silver	ppm	ASTM D5185m >3	0	0
Aluminum	ppm	ASTM D5185m >7	▲ 18	▲ 23
Lead	ppm	ASTM D5185m >12	0	0
Copper	ppm	ASTM D5185m >30	<1	<1
Tin	ppm	ASTM D5185m >9	0	<1
Vanadium	ppm	ASTM D5185m	0	0
Cadmium	ppm	ASTM D5185m	0	0

ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 0	0	0
Barium	ppm	ASTM D5185m 0	0	2
Molybdenum	ppm	ASTM D5185m 0	0	0
Manganese	ppm	ASTM D5185m	0	0
Magnesium	ppm	ASTM D5185m 0	0	<1
Calcium	ppm	ASTM D5185m 0	7	10
Phosphorus	ppm	ASTM D5185m 1800	1430	1666
Zinc	ppm	ASTM D5185m 0	3	6
Sulfur	ppm	ASTM D5185m 0	6	7

CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >60	4	5
Sodium	ppm	ASTM D5185m	0	<1
Potassium	ppm	ASTM D5185m >20	1	3
Water	%	ASTM D6304	0.054	0.075
ppm Water	ppm	ASTM D6304 >.1	545.8	751.6

FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >5000	1353	3643	637
Particles >6µm	ASTM D7647 >1300	380	959	209
Particles >14µm	ASTM D7647 >160	57	59	19
Particles >21µm	ASTM D7647 >40	18	12	5
Particles >38µm	ASTM D7647 >10	2	1	0
Particles >71µm	ASTM D7647 >3	1	0	0
Oil Cleanliness	ISO 4406 (c) >19/17/14	18/16/13	19/17/13	16/15/11


FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 0.05	0.36	0.33




OIL ANALYSIS REPORT


▲ Aluminum (ppm)




Water




Particle Trend



Water




Viscosity @ 40°C








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	NEG	NEG	NEG
Free Water	scalar	*Visual	NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 91	110	107	108

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : USPM29247
Lab Number : 05928266
Unique Number : 10608213
Test Package : IND 2

TYSON-DAKOTA CITY-USP
 P.O. BOX 515
 DAKOTA CITY, NE
 US 68731
 Contact: RICHARD KOCH

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: (605)235-2396
 F: (605)235-2960