

# **PROBLEM SUMMARY**

#### Sample Rating Trend




# LINE 18 MAIN (NORTH) (S/N 0118)

Pump Fluid

**USPI VAC 100 (--- GAL)** 

## COMPONENT CONDITION SUMMARY



#### RECOMMENDATION

Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS								
Sample Status			ABNORMAL	ABNORMAL	ABNORMAL			
Particles >4µm	ASTM D7647	>5000	<b>△</b> 53192		<b>△</b> 30904			
Particles >6µm	ASTM D7647	>1300	<b>1639</b>		<b>△</b> 6322			
Oil Cleanliness	ISO 4406 (c)	>19/17/14	<b>23/18/13</b>		<b>22/20/14</b>			

Customer Id: TYSSAI Sample No.: USPM29295 Lab Number: 05928310 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

#### **RECOMMENDED ACTIONS**

There are no recommended actions for this sample.

#### HISTORICAL DIAGNOSIS

### 23 Mar 2023 Diag: Doug Bogart

#### VIS DEBRIS



We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



#### 07 Jul 2022 Diag: Doug Bogart

150



Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



#### 06 Apr 2022 Diag: Doug Bogart

NORMAL




Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





# **OIL ANALYSIS REPORT**

#### Sample Rating Trend



# LINE 18 MAIN (NORTH) (S/N 0118) Component

Pump Fluid

**USPI VAC 100 (--- GAL)** 

#### **DIAGNOSIS**

#### Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

#### Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

#### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Jan 2021	May2021 Jan2022	Apr2022 Jul2022 Mar2023	Aug2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USPM29295	USPM24574	USPM23158
Sample Date		Client Info		19 Aug 2023	23 Mar 2023	07 Jul 2022
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>90	4	5	<1
Chromium	ppm	ASTM D5185m	>5	0	0	0
Nickel	ppm	ASTM D5185m	>5	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>3	0	0	0
Aluminum	ppm	ASTM D5185m	>7	0	1	<1
Lead	ppm	ASTM D5185m	>12	0	0	0
Copper	ppm	ASTM D5185m	>30	0	0	0
Tin	ppm	ASTM D5185m	>9	<1	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	3
Barium	ppm	ASTM D5185m	0	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	0	2	0	0
Calcium	ppm	ASTM D5185m	0	1	0	2
Phosphorus	ppm	ASTM D5185m	1800	720	315	5
Zinc	ppm	ASTM D5185m	0	4	0	<1
Sulfur	ppm	ASTM D5185m	0	595	2629	3535
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>60	5	9	4
Sodium	ppm	ASTM D5185m		0	0	3
Potassium	ppm	ASTM D5185m	>20	0	<1	0
Water	%	ASTM D6304		0.057	0.013	0.006
ppm Water	ppm	ASTM D6304	>.1	579.8	133.1	62.9
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	<b>53192</b>		▲ 30904
Particles >6µm		ASTM D7647	>1300	<b>1639</b>		<u></u> 6322
Particles >14μm		ASTM D7647	>160	44		137
Particles >21µm		ASTM D7647	>40	20		15
Particles >38µm		ASTM D7647	>10	1		0
Particles >71µm		ASTM D7647	>3	0		0
Oil Cleanliness		ISO 4406 (c)	>19/17/14	<u>^</u> 23/18/13		<u>△</u> 22/20/14
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.05	0.048	0.044	0.07



# **OIL ANALYSIS REPORT**



\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: