




# OIL ANALYSIS REPORT

Sample Rating Trend



**NORMAL**



Machine Id  
**Byron Center CAT 1 BYCM01BE**  
 Component  
**Biogas Engine**  
 Fluid  
**CHEVRON HDAX 6500 LFG GAS ENGINE OIL (--- GAL)**

## DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil.

### Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0615049</b>	WC0615046	WC0615044
Sample Date	Client Info		<b>15 Aug 2023</b>	10 Aug 2023	02 Aug 2023
Machine Age	hrs	Client Info	<b>81661</b>	81517	81338
Oil Age	hrs	Client Info	<b>480</b>	336	168
Oil Changed	Client Info		<b>Not Chngd</b>	N/A	Changed
Sample Status			<b>NORMAL</b>	NORMAL	NORMAL

## CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>4.0	<b>&lt;1.0</b>	<1.0	<1.0
Glycol	WC Method		<b>NEG</b>	NEG	NEG

## WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>15	<b>11</b>	3	<1
Chromium	ppm	ASTM D5185m	>4	<b>&lt;1</b>	<1	0
Nickel	ppm	ASTM D5185m	>2	<b>3</b>	<1	0
Titanium	ppm	ASTM D5185m		<b>0</b>	0	<1
Silver	ppm	ASTM D5185m	>5	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m	>6	<b>&lt;1</b>	3	1
Lead	ppm	ASTM D5185m	>9	<b>0</b>	<1	0
Copper	ppm	ASTM D5185m	>6	<b>2</b>	<1	<1
Tin	ppm	ASTM D5185m	>4	<b>3</b>	3	1
Vanadium	ppm	ASTM D5185m		<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m		<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		<b>0</b>	0	0
Barium	ppm	ASTM D5185m		<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m		<b>0</b>	2	2
Manganese	ppm	ASTM D5185m		<b>&lt;1</b>	<1	<1
Magnesium	ppm	ASTM D5185m		<b>12</b>	12	14
Calcium	ppm	ASTM D5185m		<b>1852</b>	1870	1804
Phosphorus	ppm	ASTM D5185m		<b>274</b>	286	270
Zinc	ppm	ASTM D5185m		<b>328</b>	334	322
Sulfur	ppm	ASTM D5185m		<b>3430</b>	3721	3082

## CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>181	<b>147</b>	117	72
Sodium	ppm	ASTM D5185m		<b>3</b>	2	1
Potassium	ppm	ASTM D5185m	>20	<b>0</b>	1	<1

## INFRA-RED




	method	limit/base	current	history1	history2	
Soot %	%	*ASTM D7844		<b>0.1</b>	0	0
Nitration	Abs/cm	*ASTM D7624	>20	<b>5.8</b>	5.8	5.5
Sulfation	Abs/.1mm	*ASTM D7415	>30	<b>23.7</b>	23.2	19.9

## FLUID DEGRADATION

	method	limit/base	current	history1	history2	
Oxidation	Abs/.1mm	*ASTM D7414	>25	<b>13.1</b>	14.0	11.1
Acid Number (AN)	mg KOH/g	ASTM D8045	1.2	<b>1.70</b>	1.73	1.20
Base Number (BN)	mg KOH/g	ASTM D2896	4.5	<b>3.05</b>	3.54	3.17











# OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 100°C	cSt	ASTM D445	14.7	<b>13.6</b>	13.4	13.3

### GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0615049 **Received** : 18 Aug 2023  
**Lab Number** : 05928426 **Diagnosed** : 21 Aug 2023  
**Unique Number** : 10608373 **Diagnostician** : Don Baldrige  
**Test Package** : MOB 2

**EDL NA Recips-Byron Center**  
 Byron Center Powerstation, 10310 South Kent Road  
 Byron Center, MI  
 US 49315  
 Contact: Jake Ripke  
 Jake.Ripke@edlenergy.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:  
F: