

PROBLEM SUMMARY

Sample Rating Trend

ISO


Machine Id **6383527 (S/N 1083)**

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

| PROBLEMATIC TEST RESULTS | | | | | | | | | |
|--------------------------|--------------|---------|-----------------|-------------|--|--|--|--|--|
| Sample Status | | | ABNORMAL | SEVERE | | | | | |
| Particles >6μm | ASTM D7647 | >1300 | <u> </u> | 73234 | | | | | |
| Particles >14μm | ASTM D7647 | >80 | 1342 | 8994 | | | | | |
| Particles >21µm | ASTM D7647 | >20 | <u> </u> | 2110 | | | | | |
| Particles >38µm | ASTM D7647 | >4 | <u> </u> | △ 36 | | | | | |
| Oil Cleanliness | ISO 4406 (c) | >/17/13 | <u>22/21/18</u> | 23/20 | | | | | |

Customer Id: COMCONNC Sample No.: KCPA005984 Lab Number: 05928798 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

19 Nov 2020 Diag: Angela Borella

ISO



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend

ISO

6383527 (S/N 1083)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

| | | | Nov2020 | Aug2023 | | |
|---------------------|--------|---------------|--------------|---------------------------|-------------------------|----------|
| SAMPLE INFORM | ΙΔΤΙΩΝ | method | limit/base | current | history1 | history2 |
| | | | IIIIIIIIIIII | | • | |
| Sample Number | | Client Info | | KCPA005984 11 Aug 2023 | KCP34902 19 Nov 2020 | |
| Sample Date | hrs | Client Info | | 24140 | 10608 | |
| Machine Age Oil Age | hrs | Client Info | | 0 | 3000 | |
| Oil Changed | 1115 | Client Info | | N/A | Changed | |
| Sample Status | | Ciletit iiiio | | ABNORMAL | SEVERE | |
| | | | | | | |
| WEAR METALS | | method | limit/base | current | history1 | history2 |
| Iron | ppm | | >50 | 2 | 14 | |
| Chromium | ppm | ASTM D5185m | >10 | 0 | 0 | |
| Nickel | ppm | ASTM D5185m | >3 | 0 | 0 | |
| Titanium | ppm | ASTM D5185m | | 0 | 0 | |
| Silver | ppm | ASTM D5185m | >2 | 0 | <1 | |
| Aluminum | ppm | ASTM D5185m | >10 | <1 | 0 | |
| Lead | ppm | ASTM D5185m | >10 | <1 | <1 | |
| Copper | ppm | ASTM D5185m | | 13 | 4 | |
| Tin | ppm | ASTM D5185m | >10 | 0 | 0 | |
| Antimony | ppm | ASTM D5185m | | | 0 | |
| Vanadium | ppm | ASTM D5185m | | 0 | 0 | |
| Cadmium | ppm | ASTM D5185m | | 0 | 0 | |
| ADDITIVES | | method | limit/base | current | history1 | history2 |
| Boron | ppm | ASTM D5185m | | 0 | 0 | |
| Barium | ppm | ASTM D5185m | 90 | 35 | 63 | |
| Molybdenum | ppm | ASTM D5185m | | 0 | <1 | |
| Manganese | ppm | ASTM D5185m | | 0 | <1 | |
| Magnesium | ppm | ASTM D5185m | 90 | 49 | 49 | |
| Calcium | ppm | ASTM D5185m | 2 | 41 | 13 | |
| Phosphorus | ppm | ASTM D5185m | | 213 | 21 | |
| Zinc | ppm | ASTM D5185m | | 222 | 35 | |
| Sulfur | ppm | ASTM D5185m | | 8747 | 17175 | |
| CONTAMINANTS | | method | limit/base | current | history1 | history2 |
| Silicon | ppm | ASTM D5185m | >25 | 12 | 4 | |
| Sodium | ppm | ASTM D5185m | | 14 | 9 | |
| Potassium | ppm | ASTM D5185m | >20 | 4 | 3 | |
| Water | % | ASTM D6304 | >0.05 | 0.018 | 0.031 | |
| ppm Water | ppm | ASTM D6304 | >500 | 184.3 | 318.3 | |
| FLUID CLEANLIN | IESS | method | limit/base | current | history1 | history2 |
| Particles >4μm | | ASTM D7647 | | 27926 | 138126 | |
| Particles >6µm | | ASTM D7647 | >1300 | △ 10739 | 7 3234 | |
| Particles >14μm | | ASTM D7647 | >80 | ▲ 1342 | 8994 | |
| Particles >21µm | | ASTM D7647 | >20 | <u> 441</u> | 2110 | |
| Particles >38µm | | ASTM D7647 | >4 | <u> 18</u> | ▲ 36 | |
| Particles >71µm | | ASTM D7647 | >3 | 0 | 3 | |
| Oil Cleanliness | | ISO 4406 (c) | >/17/13 | <u>^ 22/21/18</u> | 23/20 | |
| FLUID DEGRADA | TION | method | limit/base | current | history1 | history2 |
| | | | | | | |



OIL ANALYSIS REPORT







Certificate L2367

Sample No. Lab Number **Unique Number**

: 05928798

: KCPA005984

: 10608745

Received : 18 Aug 2023 Diagnosed : 22 Aug 2023 Diagnostician : Don Baldridge

Test Package : IND 2 (Additional Tests: KF, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

2845 ARMENTROUT DR CONCORD, NC US 28025

Contact: Service Manager

T: F: