




# PROBLEM SUMMARY


Sample Rating Trend



Machine Id  
**KAESER SFC 30ST 4465873 (S/N 1012)**  
 Component  
**Compressor**  
 Fluid  
**KAESER SIGMA (OEM) S-460 (--- GAL)**

## COMPONENT CONDITION SUMMARY

▲ Particle Trend



## RECOMMENDATION

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

## PROBLEMATIC TEST RESULTS

Sample Status			ATTENTION	NORMAL	ATTENTION
Particles >6µm	ASTM D7647	>1300	▲ 1338	469	▲ 1332
Particles >14µm	ASTM D7647	>80	▲ 148	51	▲ 84
Particles >21µm	ASTM D7647	>20	▲ 45	12	▲ 21
Oil Cleanliness	ISO 4406 (c)	>--/17/13	▲ 19/18/14	18/16/13	▲ 18/14

Customer Id: ACCSOM  
 Sample No.: KC101885  
 Lab Number: 05929587  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Angela Borella +1 800-237-1369  
[angela.borella@wearcheckusa.com](mailto:angela.borella@wearcheckusa.com)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

*There are no recommended actions for this sample.*

## HISTORICAL DIAGNOSIS

### 18 May 2022 Diag: Jonathan Hester

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 22 Jul 2020 Diag: Jonathan Hester

ISO



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 02 Aug 2019 Diag: Angela Borella

NORMAL




Resample at the next service interval to monitor. All component wear rates are normal. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id  
**KAESER SFC 30ST 4465873 (S/N 1012)**

Component

**Compressor**

Fluid

**KAESER SIGMA (OEM) S-460 (--- GAL)**

## DIAGNOSIS

### ▲ Recommendation

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### ▲ Contamination

There is a moderate amount of particulates present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>KC101885</b>	KC95993	KC83377
Sample Date	Client Info		<b>10 Aug 2023</b>	18 May 2022	22 Jul 2020
Machine Age	hrs	Client Info	<b>42597</b>	42310	39320
Oil Age	hrs	Client Info	<b>287</b>	2990	3006
Oil Changed	Client Info		<b>Not Chngd</b>	Changed	Changed
Sample Status			<b>ATTENTION</b>	NORMAL	ATTENTION

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	<b>0</b>	<1	1
Chromium	ppm	ASTM D5185m >10	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m >3	<b>0</b>	0	<1
Titanium	ppm	ASTM D5185m >3	<b>&lt;1</b>	0	0
Silver	ppm	ASTM D5185m >2	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >10	<b>0</b>	<1	0
Lead	ppm	ASTM D5185m >10	<b>0</b>	2	0
Copper	ppm	ASTM D5185m >50	<b>&lt;1</b>	2	2
Tin	ppm	ASTM D5185m >10	<b>0</b>	1	0
Antimony	ppm	ASTM D5185m	<b>---</b>	---	<1
Vanadium	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>0</b>	<1	0
Barium	ppm	ASTM D5185m 90	<b>12</b>	<1	2
Molybdenum	ppm	ASTM D5185m	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m	<b>0</b>	0	<1
Magnesium	ppm	ASTM D5185m 90	<b>71</b>	61	50
Calcium	ppm	ASTM D5185m 2	<b>0</b>	<1	<1
Phosphorus	ppm	ASTM D5185m	<b>2</b>	9	5
Zinc	ppm	ASTM D5185m	<b>0</b>	14	8

## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	<b>0</b>	<1	2
Sodium	ppm	ASTM D5185m	<b>21</b>	38	25
Potassium	ppm	ASTM D5185m >20	<b>2</b>	1	3
Water	%	ASTM D6304 >0.05	<b>0.024</b>	0.031	0.027
ppm Water	ppm	ASTM D6304 >500	<b>249.3</b>	318.8	277.7






## FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		<b>3272</b>	1384	7838
Particles >6µm	ASTM D7647	>1300	▲ <b>1338</b>	469	▲ 1332
Particles >14µm	ASTM D7647	>80	▲ <b>148</b>	51	▲ 84
Particles >21µm	ASTM D7647	>20	▲ <b>45</b>	12	▲ 21
Particles >38µm	ASTM D7647	>4	<b>3</b>	1	1
Particles >71µm	ASTM D7647	>3	<b>0</b>	0	0
Oil Cleanliness	ISO 4406 (c)	>--/17/13	▲ <b>19/18/14</b>	18/16/13	▲ 18/14

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 0.4	<b>0.35</b>	0.30	0.293


# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 46	43.9	44.5	44.4

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KC101885 **Received** : 21 Aug 2023  
**Lab Number** : 05929587 **Diagnosed** : 23 Aug 2023  
**Unique Number** : 10609534 **Diagnostician** : Angela Borella  
**Test Package** : IND 2

**ACCESS BIO**  
65 CLYDE RD  
SOMERSET, NJ  
US 08873  
Contact:

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:  
F: