

PROBLEM SUMMARY

Sample Rating Trend

ISO

Machine Id


KAESER AS 25T 4504221 (S/N 1106)

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS										
Sample Status			ABNORMAL	ABNORMAL	ABNORMAL					
Particles >6µm	ASTM D7647	>1300	<u></u> 33564	<u>▲</u> 15299						
Particles >14μm	ASTM D7647	>80	1916	▲ 1395						
Particles >21μm	ASTM D7647	>20	△ 303	<u>138</u>						
Particles >38μm	ASTM D7647	>4	<u>^</u> 7	2						
Oil Cleanliness	ISO 4406 (c)	>/17/13	<u>23/22/18</u>	<u>22/21/18</u>						

Customer Id: ISOSTI Sample No.: KC105503 Lab Number: 05929588 Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data: Angela Borella +1 800-237-1369 angela.borella@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

26 Jul 2022 Diag: Angela Borella

ISO



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



14 Jan 2022 Diag: Jonathan Hester

VIS DEBRIS



No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



08 Nov 2021 Diag: Doug Bogart

ISO



No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend



KAESER AS 25T 4504221 (S/N 1106)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		an2013 Jur	2016 May2017 Feb2	318 Apr2019 Apr2021 J	an2022	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC105503	KC105526	KC96907
Sample Date		Client Info		10 Aug 2023	26 Jul 2022	14 Jan 2022
Machine Age	hrs	Client Info		25815	23400	22144
Oil Age	hrs	Client Info		8513	1256	1672
Oil Changed		Client Info		Not Changd	Changed	Not Changd
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	<1	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	<1	<1
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m		3	4	2
Tin	ppm	ASTM D5185m	>10	0	<1	0
Antimony	ppm	ASTM D5185m				<1
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	0	0	<1
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	90	36	34	58
Calcium	ppm	ASTM D5185m	2	0	0	0
Phosphorus	ppm	ASTM D5185m		<1	<1	5
Zinc	ppm	ASTM D5185m		2	11	5
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	<1
Sodium	ppm	ASTM D5185m		15	15	27
Potassium	ppm	ASTM D5185m	>20	1	0	4
Water	%	ASTM D6304	>0.05	0.019	0.018	0.026
ppm Water	ppm	ASTM D6304	>500	193.6	185.9	263.4
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647		67174	34872	
Particles >6µm		ASTM D7647		<u>▲</u> 33564	<u>15299</u>	
Particles >14µm		ASTM D7647	>80	<u>1916</u>	▲ 1395	
Particles >21µm		ASTM D7647		<u>^</u> 303	<u>138</u>	
Particles >38µm		ASTM D7647	>4	<u>^</u> 7	2	
Particles >71µm		ASTM D7647		0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>23/22/18</u>	<u>22/21/18</u>	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2

Contact/Location: ? ? - ISOSTI



OIL ANALYSIS REPORT



To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: