


PROBLEM SUMMARY

GARDNER DENVER TYSDOS #3 AIR (S/N S057110)

Component Air Compressor Fluid USPI MAX FG AIR 46 (--- GAL)

COMPONENT CONDITION SUMMARY



No relevant graphs to display

1MENDA	TION	

R

We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

PROBLEMATIC TEST RESULTS								
Sample Status				ABNORMAL	ABNORMAL	ATTENTION		
Debris	scalar	*Visual	NONE	🔺 MODER	A MODER	LIGHT		

Customer Id: TYSHUTKS Sample No.: USPM27316 Lab Number: 05929618 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 <u>dougb@wearcheckusa.com</u>

To change component or sample information: Customer Service +1 1-800-237-1369 <u>customerservice@wearcheck.com</u>

RECOMMENDED ACTIONS									
Action	Status	Date	Done By	Description					
Change Filter			?	We recommend you service the filters on this component.					
Alert			?	We were unable to perform a particle count due to a high concentration of particles present in this sample.					

HISTORICAL DIAGNOSIS



03 May 2023 Diag: Doug Bogart

We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



view report

05 Feb 2023 Diag: Doug Bogart



Resample at the next service interval to monitor.All component wear rates are normal. There is a moderate amount of silt (particulates < 6 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

06 Nov 2022 Diag: Jonathan Hester





Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.







OIL ANALYSIS REPORT

Sample Number

hrs

hrs

Sample Date

Machine Age

Oil Changed

Sample Status

Oil Age

Machine Ic GARDNER DENVER TYSDOS #3 AIR (S/N S057110) Component

Air Compressor Fluic USPI MAX FG AIR 46 (--- GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Wear

All component wear rates are normal.

Contamination

Moderate concentration of visible dirt/debris present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	<1
Chromium	ppm	ASTM D5185m	>4	0	0	0
Nickel	ppm	ASTM D5185m	>4	0	0	0
Titanium	ppm	ASTM D5185m		<1	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	0	0
Lead	ppm	ASTM D5185m	>20	0	0	0
Copper	ppm	ASTM D5185m	>40	0	0	0
Tin	ppm	ASTM D5185m	>5	0	0	0
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		0	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	0	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	0	0	<1	<1
Calcium	ppm	ASTM D5185m	0	0	5	9
Phosphorus	ppm	ASTM D5185m	0	55	55	70
Zinc	ppm	ASTM D5185m	0	0	<1	2
Sulfur	ppm	ASTM D5185m	0	0	2	11
CONTAMINANT	c	mothod	limit/baco	ourropt	history1	history?

CONTAININANT	2	methou	iiiiii/base	current	Thistory I	mstoryz
Silicon	ppm	ASTM D5185m	>25	0	<1	2
Sodium	ppm	ASTM D5185m		<1	0	8
Potassium	ppm	ASTM D5185m	>20	0	0	2
Water	%	ASTM D6304	>0.6	0.043	0.013	0.003
ppm Water	ppm	ASTM D6304	>6000	435.4	137.4	25.6

FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000			10728
Particles >6µm	ASTM D7647	>2500			2229
Particles >14µm	ASTM D7647	>320			63
Particles >21µm	ASTM D7647	>80			11
Particles >38µm	ASTM D7647	>20			0
Particles >71µm	ASTM D7647	>4			0
Oil Cleanliness	ISO 4406 (c)	>20/18/15			🔺 21/18/13
FLUID DEGRADATION	method	limit/base	current	history1	history2

0.21

Acid Number (AN)


mg KOH/g ASTM D8045 0.16


0.17


0.35



OIL ANALYSIS REPORT








VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	VLITE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	🔺 MODER	🔺 MODER	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.6	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	45.8	49.6	49.4	49.8
SAMPLE IMAGES	S	method	limit/base	current	history1	history2

Color



Bottom



Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Page 4 of 4

Contact/Location: SCOTT OWEN - TYSHUTKS