


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



LN 24 (S/N U114108409)

Component

Vacuum Pump

BUSCH R530S (--- QTS)

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

				Aug2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USP0000520		
Sample Date		Client Info		20 Aug 2023		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>20	0		
Chromium	ppm	ASTM D5185m	>20	0		
Nickel	ppm	ASTM D5185m	>20	0		
Titanium	ppm	ASTM D5185m		<1		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>20	0		
Lead	ppm	ASTM D5185m	>20	0		
Copper	ppm	ASTM D5185m	>20	0		
Tin	ppm	ASTM D5185m	>20	0		
Vanadium	ppm	ASTM D5185m		<1		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m		0		
Calcium	ppm	ASTM D5185m		0		
Phosphorus	ppm	ASTM D5185m		<1		
Zinc	ppm	ASTM D5185m		0		
Sulfur	ppm	ASTM D5185m		30		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	2		
Sodium	ppm	ASTM D5185m		<1		
Potassium	ppm	ASTM D5185m	>20	0		
Water	%	ASTM D6304		0.001		
ppm Water	ppm	ASTM D6304	>.1	2.6		
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	5068		
Particles >6µm		ASTM D7647	>2500	851		
Particles >14µm		ASTM D7647	>640	46		
Particles >21µm		ASTM D7647	>160	11		
Particles >38µm		ASTM D7647	>40	0		
Particles >71μm		ASTM D7647	>10	0		
Oil Cleanliness		ISO 4406 (c)	>20/18/16	20/17/13		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
A at al. Niverala au (AAI)	VOLV-	ACTM D0045		0.07		


Acid Number (AN)

mg KOH/g ASTM D8045

0.07



OIL ANALYSIS REPORT





Certificate L2367

Sample No. Lab Number **Unique Number** Test Package

: USP0000520 : 05929631 : 10609578 : IND 2

Received : 21 Aug 2023 : 22 Aug 2023 Diagnosed : Doug Bogart Diagnostician

2340 FOREST LANE GARLAND, TX US 75042

Contact/Location: RICK THOMPSON - KRAGAR

Contact: RICK THOMPSON rick.thompson@kraftfoods.com T: (214)477-1515

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: (972)485-6874