




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id
HBKM02BE
Component
Biogas Engine
Fluid
SHELL MYSELLA S5 S (48 GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0775332	WC0775349	WC0775346
Sample Date	Client Info		17 Aug 2023	11 Aug 2023	17 Jul 2023
Machine Age	hrs	Client Info	100851	100718	100569
Oil Age	hrs	Client Info	172	39	566
Oil Changed	Client Info		Not Chngd	Changed	Oil Added
Sample Status			NORMAL	NORMAL	ABNORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>4.0	<1.0	<1.0	<1.0
Glycol	WC Method		NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>15	3	2	5
Chromium	ppm	ASTM D5185m	>4	<1	0	<1
Nickel	ppm	ASTM D5185m	>2	<1	0	<1
Titanium	ppm	ASTM D5185m		0	0	<1
Silver	ppm	ASTM D5185m	>5	0	0	0
Aluminum	ppm	ASTM D5185m	>6	3	<1	3
Lead	ppm	ASTM D5185m	>9	<1	0	<1
Copper	ppm	ASTM D5185m	>6	<1	<1	1
Tin	ppm	ASTM D5185m	>4	2	<1	4
Vanadium	ppm	ASTM D5185m		0	<1	<1
Cadmium	ppm	ASTM D5185m		0	0	0

ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		1	2	4
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		5	4	8
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m		24	24	27
Calcium	ppm	ASTM D5185m		1473	1463	1691
Phosphorus	ppm	ASTM D5185m	300	313	315	356
Zinc	ppm	ASTM D5185m		398	368	427
Sulfur	ppm	ASTM D5185m		3040	3191	3599

CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>181	75	39	▲ 184
Sodium	ppm	ASTM D5185m		0	1	1
Potassium	ppm	ASTM D5185m	>20	1	<1	0

INFRA-RED




	method	limit/base	current	history1	history2	
Soot %	%	*ASTM D7844		0	0	0.1
Nitration	Abs/cm	*ASTM D7624	>20	4.3	3.5	5.4
Sulfation	Abs/.1mm	*ASTM D7415	>30	18.5	16.6	21.5

FLUID DEGRADATION

	method	limit/base	current	history1	history2	
Oxidation	Abs/.1mm	*ASTM D7414	>25	11.9	10.4	15.0
Acid Number (AN)	mg KOH/g	ASTM D8045		0.63	0.52	1.20
Base Number (BN)	mg KOH/g	ASTM D2896	5.3	4.61	4.65	3.80











OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 100°C	cSt	ASTM D445	13.5	13.4	13.1	13.7

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0775332 **Received** : 21 Aug 2023
Lab Number : 05929851 **Diagnosed** : 22 Aug 2023
Unique Number : 10615122 **Diagnostician** : Sean Felton
Test Package : MOB 2

EDL NA Recips-Honeybrook
 Honey Brook Powerstation, 481 S. Churchtown Road
 Narvon, PA
 US 17555-9574
 Contact: Christian Adames
 Christian.Adames@edlenergy.com

Certificate L2367
 To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)