


PROBLEM SUMMARY


Shredder ÖRÜ (Oil Recirculate Unit)-Shredder


Hydraulic Power Pack


SHELL HYDRAULIC S1 M 68 (--- GAL)




COMPONENT CONDITION SUMMARY









RECOMMENDATION

We advise that you check for the source of water entry. We recommend you service the filters on this component. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS								
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL		
PQ		ASTM D8184		<u></u> 496	<u>▲</u> 127	<u>▲</u> 112		
Iron	ppm	ASTM D5185m	>20	41	△ 65	△ 61		
Water	%	ASTM D6304	>0.05	△ 0.142	△ 0.463	△ 0.623		
ppm Water	ppm	ASTM D6304	>500	<u> </u>	<u>▲</u> 4630	△ 6230		
Particles >6µm		ASTM D7647	>1300	<u>^</u> 2161	<u>▲</u> 4768			
Particles >14μm		ASTM D7647	>160	▲ 368	<u></u> 811			
Particles >21µm		ASTM D7647	>40	<u> </u>	<u>^</u> 273			
Particles >38μm		ASTM D7647	>10	<u> </u>	<u>42</u>			
Oil Cleanliness		ISO 4406 (c)	>19/17/14	<u> </u>	<u>^</u> 20/19/17			
Appearance	scalar	*Visual	NORML	▲ HAZY	NORML	▲ MILKY		

Customer Id: SEASEAUS Sample No.: PE0001435 Lab Number: 05930278 Test Package: PLANT



To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 ihester@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter			?	We recommend you service the filters on this component.
Check Water Access			?	We advise that you check for the source of water entry.

HISTORICAL DIAGNOSIS

05 Jul 2023 Diag: Doug Bogart

WEAR



We recommend you service the filters on this component. We recommend an early resample to monitor this condition. The iron level is abnormal. The high ferrous density (PQ) index indicates that abnormal wear is occurring. There is a high amount of particulates present in the oil. There is a light concentration of water present in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.



07 Jun 2023 Diag: Doug Bogart

WEAR



We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. The iron level is abnormal. Appearance is milky. There is a moderate concentration of water present in the oil. There is a moderate amount of visible silt present in the sample. The AN level is acceptable for this fluid.

view report

20 Apr 2023 Diag: Jonathan Hester

WEAR



We recommend you service the filters on this component. We recommend an early resample to monitor this condition. The iron level is abnormal. The high ferrous density (PQ) index indicates that abnormal wear is occurring. All other component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.






OIL ANALYSIS REPORT

Shredder Shredder **ORU** (Oil Recirculate Unit)-Shredder

Hydraulic Power Pack

SHELL HYDRAULIC S1 M 68 (--- GAL)





DIAGNOSIS

Recommendation

We advise that you check for the source of water entry. We recommend you service the filters on this component. Resample at the next service interval to monitor.

Wear

The iron level has decreased, but is still abnormal.

Contamination

Appearance is hazy. There is a high amount of particulates present in the oil. There is a light concentration of water present in the oil.

Fluid Condition

The AN level is acceptable for this fluid.

SAMPLE INFORM	ATION	method	limit/base	current	history1	history2
Sample Number	7111011	Client Info	minu bass	PE0001435	PE0000648	PE0001403
Sample Date		Client Info		18 Aug 2023	05 Jul 2023	07 Jun 2023
	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed	1113	Client Info		N/A	N/A	N/A
Sample Status		Ollerit IIIIO		ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base			
		ASTM D8184	IIIIII/Dase	current	history1	history2
PQ	10.100.100	ASTM D5185m	. 00	▲ 96 ▲ 41	▲ 65	▲ 61
Iron Chromium	ppm		>20	<1	<1	
	ppm	ASTM D5185m	>20	0		<1
Nickel	ppm	ASTM D5185m	>20		<1	0
	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m	. 20	-	2	
	ppm	ASTM D5185m	>20	0		0
Lead	ppm	ASTM D5185m	>20	<1	<1	0
	ppm	ASTM D5185m	>20	3	3	4
	ppm	ASTM D5185m	>20	0	<1	0
	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		<1	0	<1
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		<1	<1	<1
Manganese	ppm	ASTM D5185m		<1	1	1
Magnesium	ppm	ASTM D5185m		6	8	9
Calcium	ppm	ASTM D5185m		27	26	33
Phosphorus	ppm	ASTM D5185m		253	268	266
Zinc	ppm	ASTM D5185m		272	273	268
Sulfur	ppm	ASTM D5185m		625	855	780
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	2	1	<1
Sodium	ppm	ASTM D5185m		2	1	2
Potassium	ppm	ASTM D5185m	>20	0	2	<1
Water	%	ASTM D6304	>0.05	<u> </u>	△ 0.463	△ 0.623
ppm Water	ppm	ASTM D6304	>500	<u> </u>	▲ 4630	△ 6230
FLUID CLEANLINE	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	3967	<u>▲</u> 8752	
Particles >6µm		ASTM D7647	>1300	<u> </u>	4768	
Particles >14μm		ASTM D7647	>160	4 368	<u></u> 811	
Particles >21µm		ASTM D7647	>40	<u> </u>	<u>▲</u> 273	
Particles >38µm		ASTM D7647	>10	<u> </u>	4 2	
Particles >71µm		ASTM D7647	>3	2	<u>4</u>	
Oil Cleanliness		ISO 4406 (c)	>19/17/14	<u> </u>	<u>^</u> 20/19/17	
FLUID DEGRADAT	TION	method	limit/base	current	history1	history2

mg KOH/g ASTM D8045


Acid Number (AN)

0.30

0.30



OIL ANALYSIS REPORT







Certificate L2367

Sample No. Lab Number **Unique Number**

: PE0001435 : 05930278

: 10615549

Diagnosed Diagnostician : Jonathan Hester

: 24 Aug 2023

Test Package : PLANT (Additional Tests: ICP, KF, KV40, PQ, PrtCount, SCREEN)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) 601 S MYRTLE ST SEATTLE, WA US 98108

Contact: ADAM THOMAS athomas@seairon.com T: (206)682-0040 F:

Submitted By: DUANE DENOTTA