

PROBLEM SUMMARY

Sample Rating Trend

VISCOSITY

Machine Id


KAESER 2453548 (S/N 1006)


Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

COMPONENT CONDITION SUMMARY





RECOMMENDATION

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS								
Sample Status				ABNORMAL	ATTENTION	ATTENTION		
Particles >6µm		ASTM D7647	>1300	4877	1496	<u>▲</u> 1503		
Particles >14µm		ASTM D7647	>80	421	88	36		
Particles >21µm		ASTM D7647	>20	126	17	11		
Particles >38µm		ASTM D7647	>4	<u>^</u> 6	2	0		
Oil Cleanliness		ISO 4406 (c)	>/17/13	22/19/16	<u>▲</u> 18/14	<u>▲</u> 18/12		
Visc @ 40°C	cSt	ASTM D445	45	52.43	48.5	49.0		

Customer Id: BRISTOCA Sample No.: KCPA004281 Lab Number: 05930365 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 jhester@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Fluid			?	Oil and filter change at the time of sampling has been noted.
Change Filter			?	Oil and filter change at the time of sampling has been noted.

HISTORICAL DIAGNOSIS

20 Apr 2022 Diag: Don Baldridge





Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



23 Mar 2021 Diag: Don Baldridge

ISO




Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend



KAESER 2453548 (S/N 1006)

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.


Fluid Condition

The oil viscosity is higher than normal. The AN level is acceptable for this fluid.

		Ma	m2021	Apr2022 Aug20.	23	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA004281	KCP44779	KCP30007
Sample Date		Client Info		16 Aug 2023	20 Apr 2022	23 Mar 2021
Machine Age	hrs	Client Info		0	52883	48016
Oil Age	hrs	Client Info		0	2000	3000
Oil Changed		Client Info		Changed	Changed	Changed
Sample Status				ABNORMAL	ATTENTION	ATTENTION
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m	>10	0	0	0
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	8	4	4
Tin	ppm	ASTM D5185m	>10	0	<1	0
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	<1
Barium	ppm	ASTM D5185m	90	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	100	0	0	1
Calcium	ppm	ASTM D5185m	0	0	0	0
Phosphorus	ppm	ASTM D5185m	0	0	0	0
Zinc	ppm	ASTM D5185m	0	0	0	0
Sulfur	ppm	ASTM D5185m	23500	24845	16764	18400
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	8	<1	0
Sodium	ppm	ASTM D5185m		<1	0	0
Potassium	ppm	ASTM D5185m	>20	<1	0	<1
Water	%	ASTM D6304		0.003	0.003	0.008
ppm Water	ppm	ASTM D6304	>500	35.0	37.4	80.7
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647		20576	7737	13642
Particles >6µm		ASTM D7647	>1300	<u>4877</u>	<u></u> 1496	<u></u> 1503
Particles >14µm		ASTM D7647	>80	<u>421</u>	<u></u> 88	36
Particles >21µm		ASTM D7647	>20	<u> </u>	17	11
Particles >38μm		ASTM D7647	>4	<u>^</u> 6	2	0
Particles >71µm		ASTM D7647		0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>22/19/16</u>	<u> </u>	△ 18/12
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2



OIL ANALYSIS REPORT



* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: