




PROBLEM SUMMARY

Sample Rating Trend




Machine Id
6902277 (S/N 1350)

Component
Compressor
Fluid
KAESER SIGMA (OEM) S-460 (--- GAL)

COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status	ASTM D7647	ISO 4406 (c)	ABNORMAL	ABNORMAL	ABNORMAL
Particles >6µm	>1300	>--/17/13	▲ 30039	---	---
Particles >14µm	>80	>--/17/13	▲ 2955	---	---
Particles >21µm	>20	>--/17/13	▲ 816	---	---
Particles >38µm	>4	>--/17/13	▲ 37	---	---
Oil Cleanliness	ISO 4406 (c)	>--/17/13	▲ 23/22/19	---	---
Debris	scalar *Visual	NONE	▲ MODER	▲ MODER	▲ MODER

Customer Id: FROBURN
Sample No.: KCPA002836
Lab Number: 05930391
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Angela Borella +1 800-237-1369
angela.borella@wearcheckusa.com

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Fluid	---	---	?	Oil and filter change at the time of sampling has been noted.
Change Filter	---	---	?	Oil and filter change at the time of sampling has been noted.

HISTORICAL DIAGNOSIS

08 Aug 2022 Diag: Jonathan Hester

WATER



Oil and filter change at the time of sampling has been noted. We were unable to perform a particle count due to a high concentration of particles present in this sample. We recommend an early resample in 500 hours to monitor this condition. All component wear rates are normal. Free water present. There is a light concentration of water present in the oil. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

[view report](#)



25 May 2021 Diag: Jonathan Hester

WATER



Oil and filter change at the time of sampling has been noted. We recommend an early resample in 500 hours to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. There is a light concentration of water present in the oil. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

[view report](#)



13 Apr 2020 Diag: Jonathan Hester

WATER



Oil and filter change at the time of sampling has been noted. We recommend an early resample in 500 hours to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Appearance is hazy. There is a light concentration of water present in the oil. High concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


[view report](#)





OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id
6902277 (S/N 1350)
 Component
Compressor
 Fluid
KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation
 Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear
 All component wear rates are normal.

Contamination
 There is a high amount of particulates present in the oil. Moderate concentration of visible dirt/debris present in the oil.

Fluid Condition
 The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	KCPA002836	KC102817	KC92843
Sample Date	Client Info	17 Aug 2023	08 Aug 2022	25 May 2021
Machine Age	hrs	9344	7126	4335
Oil Age	hrs	8427	2200	0
Oil Changed	Client Info	Changed	Changed	Changed
Sample Status		ABNORMAL	ABNORMAL	ABNORMAL

WEAR METALS

method	limit/base	current	history1	history2
Iron ppm	ASTM D5185m >50	<1	<1	0
Chromium ppm	ASTM D5185m >10	0	0	0
Nickel ppm	ASTM D5185m >3	0	0	0
Titanium ppm	ASTM D5185m >3	0	0	0
Silver ppm	ASTM D5185m >2	0	0	<1
Aluminum ppm	ASTM D5185m >10	0	0	0
Lead ppm	ASTM D5185m >10	0	0	0
Copper ppm	ASTM D5185m >50	19	20	11
Tin ppm	ASTM D5185m >10	0	0	<1
Antimony ppm	ASTM D5185m	---	---	0
Vanadium ppm	ASTM D5185m	0	0	0
Cadmium ppm	ASTM D5185m	0	0	0

ADDITIVES

method	limit/base	current	history1	history2
Boron ppm	ASTM D5185m	0	<1	9
Barium ppm	ASTM D5185m 90	0	0	0
Molybdenum ppm	ASTM D5185m	0	0	0
Manganese ppm	ASTM D5185m	0	<1	0
Magnesium ppm	ASTM D5185m 90	2	<1	<1
Calcium ppm	ASTM D5185m 2	0	0	0
Phosphorus ppm	ASTM D5185m	0	2	4
Zinc ppm	ASTM D5185m	0	0	0
Sulfur ppm	ASTM D5185m	19262	12531	12477

CONTAMINANTS

method	limit/base	current	history1	history2
Silicon ppm	ASTM D5185m >25	<1	<1	0
Sodium ppm	ASTM D5185m	4	<1	2
Potassium ppm	ASTM D5185m >20	<1	0	0
Water %	ASTM D6304 >0.05	0.012	▲ 0.091	▲ 0.264
ppm Water	ASTM D6304 >500	120.5	▲ 910	▲ 2640






FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	78620	---	---
Particles >6µm	ASTM D7647 >1300	▲ 30039	---	---
Particles >14µm	ASTM D7647 >80	▲ 2955	---	---
Particles >21µm	ASTM D7647 >20	▲ 816	---	---
Particles >38µm	ASTM D7647 >4	▲ 37	---	---
Particles >71µm	ASTM D7647 >3	2	---	---
Oil Cleanliness	ISO 4406 (c) >--/17/13	▲ 23/22/19	---	---

FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN) mg KOH/g	ASTM D8045 0.4	0.30	0.28	0.298


OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	▲ MODER	▲ MODER	▲ MODER
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	0.2%
Free Water	scalar	*Visual		NEG	▲ 1.0

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 46	44.2	43.9	44.2

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KCPA002836 **Received** : 21 Aug 2023
Lab Number : 05930391 **Diagnosed** : 23 Aug 2023
Unique Number : 10615662 **Diagnostician** : Angela Borella
Test Package : IND 2 (Additional Tests: KF, PrtCount)

FROST CONVERTING SYSTEMS INC
 2056 WILLOW SPRINGS LN
 BURLINGTON, NC
 US 27215
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: