


# **OIL ANALYSIS REPORT**

Sample Rating Trend



NORMAL



Machine Id

# KAESER CSD 75 4409844 (S/N 1071)

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

## DIAGNOSIS

# Recommendation

Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

# **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Mar2015 De	pc2018 Sep2020 Apr	2021 Sep 2021 Jun 2022 I	Feb 2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA006750	KCP55967	KCP47303D
Sample Date		Client Info		16 Aug 2023	07 Feb 2023	11 Oct 2022
Machine Age	hrs	Client Info		52202	49373	47946
Oil Age	hrs	Client Info		9846	2692	1265
Oil Changed		Client Info		Changed	Changed	Not Changd
Sample Status				NORMAL	ABNORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	2	8
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	<1	0
Aluminum	ppm	ASTM D5185m	>10	0	<1	<1
Lead	ppm	ASTM D5185m	>10	0	0	<1
Copper	ppm	ASTM D5185m	>50	1	4	6
Tin	ppm	ASTM D5185m	>10	0	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	40	43	64
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	<1	<1
Magnesium	ppm	ASTM D5185m	90	95	85	89
Calcium	ppm	ASTM D5185m	2	0	3	4
Phosphorus	ppm	ASTM D5185m		0	4	7
Zinc	ppm	ASTM D5185m		0	4	3
Sulfur	ppm	ASTM D5185m		24502	21822	23207
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1	2	1
Sodium	ppm	ASTM D5185m		12	23	12
Potassium	ppm	ASTM D5185m	>20	2	2	0
Water	%	ASTM D6304	>0.05	0.032	0.023	0.022
ppm Water	ppm	ASTM D6304	>500	320.3	234.3	222.1
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		829	63675	
Particles >6µm		ASTM D7647	>1300	149	<u>11594</u>	
Particles >14μm		ASTM D7647	>80	9	<u>129</u>	
Particles >21µm		ASTM D7647	>20	2	9	
Particles >38μm		ASTM D7647	>4	0	1	
Particles >71µm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	17/14/10	<u>\$\rightarrow\$ 23/21/14</u>	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.42	0.38	0.50



# **OIL ANALYSIS REPORT**





Certificate L2367

Laboratory Sample No. Lab Number **Unique Number** 

: KCPA006750 : 05930405

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : 10615676

Received : 21 Aug 2023 Diagnosed

: 23 Aug 2023 Diagnostician : Angela Borella Test Package : IND 2 ( Additional Tests: KF, PrtCount )

US 37127 Contact: SERVICE MANAGER

2020 JOE B JACKSON PKWY

MURFREESBORO, TN

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: