


# PROBLEM SUMMARY

Sample Rating Trend



## VISCOSITY




Machine Id  
**6808194 (S/N 1585)**


Component  
**Compressor**  
Fluid  
**KAESER SIGMA (OEM) M-460 (--- GAL)**

### COMPONENT CONDITION SUMMARY

▲ Viscosity @ 40°C



▲ Particle Trend



### RECOMMENDATION

No corrective action is recommended at this time.  
Resample at the next service interval to monitor.

### PROBLEMATIC TEST RESULTS

Sample Status			<b>ABNORMAL</b>	ATTENTION	ATTENTION
Particles >14µm	ASTM D7647	>80	▲ <b>99</b>	▲ 111	▲ 133
Particles >21µm	ASTM D7647	>20	▲ <b>26</b>	▲ 31	▲ 34
Oil Cleanliness	ISO 4406 (c)	>--/17/13	▲ <b>19/17/14</b>	▲ 19/17/14	▲ 18/14
Visc @ 40°C	cSt	ASTM D445 45	▲ <b>56.78</b>	50.9	44.2

Customer Id: GEISUW  
Sample No.: KCPA002677  
Lab Number: 05930414  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Jonathan Hester +1 919-379-4092 x4092  
[jhester@wearcheckusa.com](mailto:jhester@wearcheckusa.com)

To change component or sample information:  
Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

*There are no recommended actions for this sample.*

## HISTORICAL DIAGNOSIS

### 05 May 2022 Diag: Don Baldrige

ISO



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



---

### 28 Dec 2020 Diag: Jonathan Hester

ISO



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





# OIL ANALYSIS REPORT

Sample Rating Trend



**VISCOSITY**



Machine Id  
**6808194 (S/N 1585)**  
 Component  
**Compressor**  
 Fluid  
**KAESER SIGMA (OEM) M-460 (--- GAL)**

**DIAGNOSIS**

- ▲ **Recommendation**  
 No corrective action is recommended at this time. Resample at the next service interval to monitor.
- Wear**  
 All component wear rates are normal.
- ▲ **Contamination**  
 There is a moderate amount of particulates present in the oil.
- ▲ **Fluid Condition**  
 The oil viscosity is higher than normal. The AN level is acceptable for this fluid.

**SAMPLE INFORMATION**

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>KCPA002677</b>	KCP48090	KCP28850
Sample Date	Client Info		<b>09 Aug 2023</b>	05 May 2022	28 Dec 2020
Machine Age	hrs	Client Info	<b>18051</b>	11398	3525
Oil Age	hrs	Client Info	<b>13885</b>	2500	3525
Oil Changed	Client Info		<b>N/A</b>	Changed	Changed
Sample Status			<b>ABNORMAL</b>	ATTENTION	ATTENTION

**WEAR METALS**

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	<b>0</b>	0	<1
Chromium	ppm	ASTM D5185m >10	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m >3	<b>0</b>	0	0
Titanium	ppm	ASTM D5185m >3	<b>0</b>	0	0
Silver	ppm	ASTM D5185m >2	<b>0</b>	<1	0
Aluminum	ppm	ASTM D5185m >10	<b>0</b>	0	0
Lead	ppm	ASTM D5185m >10	<b>0</b>	0	0
Copper	ppm	ASTM D5185m >50	<b>11</b>	10	7
Tin	ppm	ASTM D5185m >10	<b>0</b>	0	0
Antimony	ppm	ASTM D5185m	<b>---</b>	---	0
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

**ADDITIVES**

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 0	<b>0</b>	1	0
Barium	ppm	ASTM D5185m 90	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m 0	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m	<b>0</b>	0	0
Magnesium	ppm	ASTM D5185m 100	<b>0</b>	0	2
Calcium	ppm	ASTM D5185m 0	<b>0</b>	0	0
Phosphorus	ppm	ASTM D5185m 0	<b>0</b>	2	8
Zinc	ppm	ASTM D5185m 0	<b>0</b>	0	6
Sulfur	ppm	ASTM D5185m 23500	<b>23196</b>	12936	14732

**CONTAMINANTS**

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	<b>2</b>	<1	<1
Sodium	ppm	ASTM D5185m	<b>1</b>	<1	0
Potassium	ppm	ASTM D5185m >20	<b>0</b>	0	<1
Water	%	ASTM D6304 >0.05	<b>0.010</b>	0.003	0.010
ppm Water	ppm	ASTM D6304 >500	<b>109.6</b>	35.7	102.2






**FLUID CLEANLINESS**

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		<b>3472</b>	3759	4657
Particles >6µm	ASTM D7647	>1300	<b>1114</b>	1109	▲ 1326
Particles >14µm	ASTM D7647	>80	▲ <b>99</b>	▲ 111	▲ 133
Particles >21µm	ASTM D7647	>20	▲ <b>26</b>	▲ 31	▲ 34
Particles >38µm	ASTM D7647	>4	<b>1</b>	1	1
Particles >71µm	ASTM D7647	>3	<b>0</b>	0	0
Oil Cleanliness	ISO 4406 (c)	>--/17/13	▲ <b>19/17/14</b>	▲ 19/17/14	▲ 18/14

**FLUID DEGRADATION**

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 1.0	<b>0.53</b>	0.50	0.335


# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 45	▲ 56.78	50.9	44.2

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KCPA002677 **Received** : 21 Aug 2023  
**Lab Number** : 05930414 **Diagnosed** : 24 Aug 2023  
**Unique Number** : 10615685 **Diagnostician** : Jonathan Hester  
**Test Package** : IND 2 ( Additional Tests: KF, PrtCount )

**GEIGER AUTOMOTIVE**  
 375 SATELLITE BLVD  
 SUWANEE, GA  
 US 30024  
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:  
F: