

PROBLEM SUMMARY

Sample Rating Trend

WATER

A


KAESER 7833617


Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

COMPONENT CONDITION SUMMARY





RECOMMENDATION

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

| PROBLEMATIC TEST RESULTS | | | | | | | | | | |
|--------------------------|--------|--------------|---------|-----------------|----------------------|--------|--|--|--|--|
| Sample Status | | | | ABNORMAL | ABNORMAL | NORMAL | | | | |
| Water | % | ASTM D6304 | >0.05 | △ 0.280 | 0.010 | 0.01 | | | | |
| ppm Water | ppm | ASTM D6304 | >500 | 2800 | 107.4 | 100.0 | | | | |
| Particles >14μm | | ASTM D7647 | >80 | <u>^</u> 201 | ^ 269 | 78 | | | | |
| Particles >21μm | | ASTM D7647 | >20 | ▲ 68 | 1 70 | 16 | | | | |
| Particles >38μm | | ASTM D7647 | >4 | <u> 10</u> | <u>\$\lambda\$</u> 5 | 2 | | | | |
| Oil Cleanliness | | ISO 4406 (c) | >/17/13 | 18/17/15 | 22/20/15 | 17/13 | | | | |
| Appearance | scalar | *Visual | NORML | ▲ HAZY | NORML | NORML | | | | |

Customer Id: UNIFAYAR Sample No.: KC111111 Lab Number: 05930429 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 jhester@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

03 Apr 2023 Diag: Don Baldridge

ISO



No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



29 Mar 2022 Diag: Doug Bogart

NORMAL



No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend



WATER



KAESER 7833617

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

Appearance is hazy. There is a high amount of particulates present in the oil. There is a light concentration of water present in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

| Mar2022 Apr2023 Aug2023 | | | | | | | |
|-------------------------|----------|--------------|------------|-------------|-----------------|-------------|--|
| SAMPLE INFORM | MATION | method | limit/base | current | history1 | history2 | |
| Sample Number | | Client Info | | KC111111 | KC103592 | KC89754 | |
| Sample Date | | Client Info | | 14 Aug 2023 | 03 Apr 2023 | 29 Mar 2022 | |
| Machine Age | hrs | Client Info | | 2259 | 1874 | 1094 | |
| Oil Age | hrs | Client Info | | 1213 | 1100 | 1094 | |
| Oil Changed | | Client Info | | Not Changd | Not Changd | Not Changd | |
| Sample Status | | | | ABNORMAL | ABNORMAL | NORMAL | |
| WEAR METALS | | method | limit/base | current | history1 | history2 | |
| Iron | ppm | ASTM D5185m | >50 | 0 | <1 | <1 | |
| Chromium | ppm | ASTM D5185m | >10 | 0 | 0 | 0 | |
| Nickel | ppm | ASTM D5185m | >3 | 0 | <1 | 0 | |
| Titanium | ppm | ASTM D5185m | >3 | 0 | 0 | 0 | |
| Silver | ppm | ASTM D5185m | >2 | 0 | 0 | 0 | |
| Aluminum | ppm | ASTM D5185m | >10 | 1 | 2 | 2 | |
| Lead | ppm | ASTM D5185m | >10 | 0 | <1 | 0 | |
| Copper | ppm | ASTM D5185m | >50 | 4 | 5 | 6 | |
| Tin | ppm | ASTM D5185m | >10 | 0 | 0 | 0 | |
| Vanadium | ppm | ASTM D5185m | | 0 | 0 | 0 | |
| Cadmium | ppm | ASTM D5185m | | 0 | 0 | 0 | |
| ADDITIVES | | method | limit/base | current | history1 | history2 | |
| Boron | ppm | ASTM D5185m | | 0 | 0 | <1 | |
| Barium | ppm | ASTM D5185m | 90 | 0 | 2 | 0 | |
| Molybdenum | ppm | ASTM D5185m | | 0 | 0 | 0 | |
| Manganese | ppm | ASTM D5185m | | <1 | <1 | 0 | |
| Magnesium | ppm | ASTM D5185m | 90 | 34 | 20 | 21 | |
| Calcium | ppm | ASTM D5185m | 2 | 0 | 0 | 0 | |
| Phosphorus | ppm | ASTM D5185m | | <1 | 9 | <1 | |
| Zinc | ppm | ASTM D5185m | | 11 | 16 | 9 | |
| CONTAMINANTS | 3 | method | limit/base | current | history1 | history2 | |
| Silicon | ppm | ASTM D5185m | >25 | 2 | 2 | 0 | |
| Sodium | ppm | ASTM D5185m | | 9 | 2 | 2 | |
| Potassium | ppm | ASTM D5185m | >20 | 4 | 5 | 7 | |
| Water | % | ASTM D6304 | >0.05 | <u> </u> | 0.010 | 0.01 | |
| ppm Water | ppm | ASTM D6304 | >500 | 2800 | 107.4 | 100.0 | |
| FLUID CLEANLIN | IESS | method | limit/base | current | history1 | history2 | |
| Particles >4µm | | ASTM D7647 | | 2166 | 32216 | 4294 | |
| Particles >6µm | | ASTM D7647 | >1300 | 1180 | △ 9302 | 1076 | |
| Particles >14µm | | ASTM D7647 | >80 | <u> </u> | △ 269 | 78 | |
| Particles >21µm | | ASTM D7647 | >20 | <u></u> 68 | <u>^</u> 70 | 16 | |
| Particles >38µm | | ASTM D7647 | >4 | <u> </u> | <u> 5</u> | 2 | |
| Particles >71µm | | ASTM D7647 | >3 | 1 | 0 | 0 | |
| Oil Cleanliness | | ISO 4406 (c) | >/17/13 | <u> </u> | <u>22/20/15</u> | 17/13 | |
| FLUID DEGRADA | ATION | method | limit/base | current | history1 | history2 | |
| Acid Number (AN) | mg KOH/g | ASTM D8045 | 0.4 | 0.37 | 0.35 | 0.34 | |



OIL ANALYSIS REPORT



* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: