



# **PROBLEM SUMMARY**

#### Machine Id **1231 LOCO** Component **Air Compressor** Fluid **NOT GIVEN (2 GAL)**

### COMPONENT CONDITION SUMMARY







#### RECOMMENDATION

We recommend you service the filters on this component. We advise that you inspect for the source(s) of wear. We recommend an early resample to monitor this condition. Due to an abnormal test result it is recommended to contact Stauff Corp at (201)-444-7800 for help resolving the issue.

# PROBLEMATIC TEST RESULTS

PROBLEMATIC TEST RESULTS								
Sample Status				SEVERE	ABNORMAL	ABNORMAL		
Iron	ppm	ASTM D5185m	>50	🛑 154	<b>5</b> 9	<u> </u>		
Particles >4µm		ASTM D7647	>20000	🔺 206710	🔺 116658	148030		
Particles >6µm		ASTM D7647	>2500	🔺 131388	<b>A</b> 7219	<b>4</b> 1573		
Particles >14µm		ASTM D7647	>320	<u> </u>	176	<b>A</b> 894		
Particles >21µm		ASTM D7647	>80	<u> </u>	35	<b>1</b> 51		
Oil Cleanliness		ISO 4406 (c)	>21/18/15	<b>A</b> 25/24/18	<b>4</b> /20/15	🔺 24/23/17		

Customer Id: NUCCOFST Sample No.: ST40604 Lab Number: 05930432 Test Package: IND 2



To manage this report scan the QR code

*To discuss the diagnosis or test data:* Jonathan Hester +1 919-379-4092 x4092 <u>jhester@wearcheckusa.com</u>

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

DECON	ACTIONS
	ACTIONS

Action	Status	Date	Done By	Description	
Inspect Wear Source			?	We advise that you inspect for the source(s) of wear.	
Change Filter			?	We recommend you service the filters on this component.	
Resample			?	We recommend an early resample to monitor this condition.	
Contact Required			?	Due to an abnormal test result it is recommended to contact Stauff Corp at (201)-444-7800 for help resolving the issue.	

### HISTORICAL DIAGNOSIS



#### 12 Nov 2022 Diag: Jonathan Hester

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample. Due to an abnormal test result it is recommended to contact Stauff Corp at (201)-444-7800 for help resolving the issue. The iron level is abnormal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid.





#### 26 Aug 2021 Diag: Angela Borella

We recommend you service the filters on this component. We advise that you inspect for the source(s) of wear. Resample at the next service interval to monitor. Due to an abnormal test result it is recommended to contact Stauff Corp at (201)-444-7800 for help resolving the issue. The iron level is abnormal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



#### 08 May 2021 Diag: Don Baldridge

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. Due to an abnormal test result it is recommended to contact Stauff Corp at (201)-444-7800 for help resolving the issue. The iron level is abnormal. Bearing and/or bushing wear is indicated. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.



view report





# **OIL ANALYSIS REPORT**

Sample Rating Trend

WEAR

Machine Id 1231 LOCO Component Air Compressor Fluid NOT GIVEN (2 GAL)

#### DIAGNOSIS

#### Recommendation

We recommend you service the filters on this component. We advise that you inspect for the source(s) of wear. We recommend an early resample to monitor this condition. Due to an abnormal test result it is recommended to contact Stauff Corp at (201)-444-7800 for help resolving the issue.

### Wear

The iron level is severe.

## Contamination

There is a high amount of particulates present in the oil.

#### Fluid Condition

The AN level is acceptable for this fluid.

		b2011 May20	112 Aug2013 Feb2015	Aug2016 Nov2017 Feb2019	Feb2021	
SAMPLE INFOR	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		ST40604	ST40556	ST42437
Sample Date		Client Info		20 Aug 2023	12 Nov 2022	26 Aug 2021
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				SEVERE	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	🛑 154	<b>5</b> 9	<b>A</b> 78
Chromium	ppm	ASTM D5185m	>4	1	0	<1
Nickel	ppm	ASTM D5185m	>4	<1	0	<1
Titanium	ppm	ASTM D5185m		<1	<1	<1
Silver	ppm	ASTM D5185m		0	2	0
Aluminum	ppm	ASTM D5185m		3	1	2
Lead	ppm	ASTM D5185m	>20	16	15	11
Copper	ppm	ASTM D5185m	>40	24	20	16
Tin	ppm	ASTM D5185m	>5	3	2	4
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		<1	0	<1
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		26	35	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		20	20	<1
Manganese	ppm	ASTM D5185m		3	2	2
Magnesium	ppm	ASTM D5185m		373	334	<1
Calcium	ppm	ASTM D5185m		434	435	28
Phosphorus	ppm	ASTM D5185m		478	454	293
Zinc	ppm	ASTM D5185m		570	534	298
Sulfur	ppm	ASTM D5185m		1941	1857	659
CONTAMINANT	S	method	limit/base		history1	history2
Silicon	ppm	ASTM D5185m	>25	10	4	6
Sodium	ppm	ASTM D5185m		9	3	6
Potassium	ppm	ASTM D5185m	>20	2	2	0
Water	%	ASTM D6304	>0.6	0.036	0.030	0.006
ppm Water	ppm	ASTM D6304	>6000	365.2	304.4	63.0
FLUID CLEANLI	NESS	method	limit/base		history1	history2
Particles >4µm		ASTM D7647	>20000	<u> </u>	<u>▲</u> 116658	<u> </u>
Particles >6µm		ASTM D7647	>2500	<u> </u>	▲ 7219	<b>4</b> 1573
Particles >14µm		ASTM D7647	>320	<u> </u>	176	<b>8</b> 94
Particles >21µm		ASTM D7647	>80	<u> </u>	35	<u> </u>
Particles >38µm		ASTM D7647	>20	2	3	8
Particles >71µm		ASTM D7647		0	0	0
Oil Cleanliness		ISO 4406 (c)	>21/18/15	<u> </u>	🔺 24/20/15	🔺 24/23/17

FLUID DEGRADATION Acid Number (AN)

0.764 0.68

Report Id: NUCCOFST [WUSCAR] 05930432 (Generated: 08/24/2023 16:29:38) Rev: 1

mg KOH/g ASTM D8045


Contact/Location: JOHN REUTER - NUCCOFST

0.516




250

# **OIL ANALYSIS REPORT**





Bottom



Contact/Location: JOHN REUTER - NUCCOFST