




# PROBLEM SUMMARY

Sample Rating Trend

DEGRADATION




Machine Id  
**ATLAS COPCO AIR COMP 3 (S/N AFF172836)**  
 Component  
**Air Compressor**  
 Fluid  
**USPI MAX FG AIR 46 (--- GAL)**




## COMPONENT CONDITION SUMMARY


### Acid Number



### Water



### Viscosity @ 40°C



## RECOMMENDATION

Recommend drain oil if not already done and flush with cleaner before refilling with oil.

## PROBLEMATIC TEST RESULTS

Sample Status				SEVERE	NORMAL	NORMAL
Water	%	ASTM D6304	>0.1	▲ <b>0.109</b>	0.041	0.025
ppm Water	ppm	ASTM D6304	>1000	▲ <b>1096.8</b>	416.2	250.6
Acid Number (AN)	mg KOH/g	ASTM D8045	0.16	● <b>14.04</b>	1.68	1.55
Visc @ 40°C	cSt	ASTM D445	45.8	▲ <b>88.1</b>	47.3	46.0

Customer Id: TYSGOO  
 Sample No.: USP242333  
 Lab Number: 05930458  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Doug Bogart +1 (800)237-1369 x4016  
[dougb@wearcheckusa.com](mailto:dougb@wearcheckusa.com)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Fluid	---	---	?	Recommend drain oil if not already done and flush with cleaner before refilling with oil.
Flush System	---	---	?	Recommend drain oil if not already done and flush with cleaner before refilling with oil.

## HISTORICAL DIAGNOSIS

### 21 May 2023 Diag: Doug Bogart

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

[view report](#)



### 02 Apr 2023 Diag: Doug Bogart

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

[view report](#)



### 14 Feb 2023 Diag: Doug Bogart

DEGRADATION



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. An increase in the AN level is noted. Confirmed.


[view report](#)





# OIL ANALYSIS REPORT

Sample Rating Trend



DEGRADATION



Machine Id  
**ATLAS COPCO AIR COMP 3 (S/N AFF172836)**  
 Component  
**Air Compressor**  
 Fluid  
**USPI MAX FG AIR 46 (--- GAL)**

## DIAGNOSIS

### Recommendation

Recommend drain oil if not already done and flush with cleaner before refilling with oil.

### Wear

All component wear rates are normal.

### Contamination

There is a light concentration of water present in the oil. The amount and size of particulates present in the system are acceptable.

### Fluid Condition

The AN level is above the recommended limit. The oil viscosity is higher than normal. Confirmed.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>USP242333</b>	USPM28267	USPM20156
Sample Date	Client Info		<b>20 Aug 2023</b>	21 May 2023	02 Apr 2023
Machine Age	hrs	Client Info	<b>0</b>	0	0
Oil Age	hrs	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>SEVERE</b>	NORMAL	NORMAL

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >70	<b>&lt;1</b>	<1	1
Chromium	ppm	ASTM D5185m >15	<b>&lt;1</b>	0	0
Nickel	ppm	ASTM D5185m >6	<b>0</b>	0	0
Titanium	ppm	ASTM D5185m	<b>0</b>	0	0
Silver	ppm	ASTM D5185m	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >10	<b>0</b>	0	<1
Lead	ppm	ASTM D5185m >20	<b>0</b>	0	0
Copper	ppm	ASTM D5185m >80	<b>4</b>	3	2
Tin	ppm	ASTM D5185m >15	<b>&lt;1</b>	0	0
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>&lt;1</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 0	<b>0</b>	0	0
Barium	ppm	ASTM D5185m 0	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m 0	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Magnesium	ppm	ASTM D5185m 0	<b>&lt;1</b>	0	0
Calcium	ppm	ASTM D5185m 0	<b>0</b>	0	0
Phosphorus	ppm	ASTM D5185m 0	<b>2</b>	1	2
Zinc	ppm	ASTM D5185m 0	<b>4</b>	6	4
Sulfur	ppm	ASTM D5185m 0	<b>26</b>	0	5

## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >12	<b>2</b>	<1	0
Sodium	ppm	ASTM D5185m	<b>5</b>	0	<1
Potassium	ppm	ASTM D5185m >20	<b>2</b>	<1	0
Water	%	ASTM D6304 >0.1	<b>▲ 0.109</b>	0.041	0.025
ppm Water	ppm	ASTM D6304 >1000	<b>▲ 1096.8</b>	416.2	250.6

## FLUID CLEANLINESS






	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	<b>1886</b>	838	100
Particles >6µm	ASTM D7647	>2500	<b>480</b>	284	24
Particles >14µm	ASTM D7647	>320	<b>46</b>	28	4
Particles >21µm	ASTM D7647	>80	<b>14</b>	10	1
Particles >38µm	ASTM D7647	>20	<b>1</b>	0	0
Particles >71µm	ASTM D7647	>4	<b>0</b>	0	0
Oil Cleanliness	ISO 4406 (c)	>20/18/15	<b>18/16/13</b>	17/15/12	14/12/9

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 0.16	<b>▲ 14.04</b>	1.68	1.55




# OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	<b>LIGHT</b>	NONE
Yellow Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE
Precipitate	scalar	*Visual	NONE	<b>NONE</b>	NONE
Silt	scalar	*Visual	NONE	<b>NONE</b>	NONE
Debris	scalar	*Visual	NONE	<b>NONE</b>	NONE
Sand/Dirt	scalar	*Visual	NONE	<b>NONE</b>	NONE
Appearance	scalar	*Visual	NORML	<b>NORML</b>	NORML
Odor	scalar	*Visual	NORML	<b>NORML</b>	NORML
Emulsified Water	scalar	*Visual	>0.1	<b>NEG</b>	NEG
Free Water	scalar	*Visual		<b>NEG</b>	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	45.8	<b>88.1</b>	47.3

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------




## GRAPHS


### Ferrous Alloys




### Non-ferrous Metals




### Particle Count



### Viscosity @ 40°C



### Acid Number



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : USP242333 **Received** : 21 Aug 2023  
**Lab Number** : 05930458 **Diagnosed** : 22 Aug 2023  
**Unique Number** : 10615729 **Diagnostician** : Doug Bogart  
**Test Package** : IND 2

**TYSON -GOODLETTSVILLE-USP**  
 201 CARTWRIGHT STREET  
 GOODLETTSVILLE, TN  
 US 37072  
 Contact: JOHN BAKER

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)