




PROBLEM SUMMARY

Area
PRESS
Machine Id
0809SB01

Component
Rear Gearbox
Fluid
KLUBER Klübersynth GH 6 ISO 320 (--- LTR)

Sample Rating Trend




WATER




COMPONENT CONDITION SUMMARY

▲ Water



▲ Particle Trend



RECOMMENDATION

We advise that you check for the source of water entry. We recommend you service the filters on this component. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	SEVERE	SEVERE
Water	%	ASTM D6304	>0.2	▲ 0.564	---	---
ppm Water	ppm	ASTM D6304	>2000	▲ 5641.1	---	---
Particles >4µm		ASTM D7647	>20000	▲ 171801	● 185107	● 190491
Particles >6µm		ASTM D7647	>5000	▲ 63797	● 62276	● 65016
Particles >14µm		ASTM D7647	>640	▲ 3259	▲ 3578	● 2694
Particles >21µm		ASTM D7647	>160	▲ 621	▲ 778	● 485
Oil Cleanliness		ISO 4406 (c)	>21/19/16	▲ 25/23/19	● 25/23/19	● 25/23/19

Customer Id: FLAMONNC
Sample No.: WC0668047
Lab Number: 05930871
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Don Baldrige +1
don.b505@comcast.net

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.
Resample	---	---	?	We recommend an early resample to monitor this condition.
Check Water Access	---	---	?	We advise that you check for the source of water entry.

HISTORICAL DIAGNOSIS

20 Apr 2023 Diag: Wes Davis

ISO



We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. All component wear rates are normal. There is a high amount of particulates (2 to 100 microns in size) present in the oil. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code. The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

view report



15 Jul 2021 Diag: Doug Bogart

ISO



We recommend you service the filters on this component. We recommend an early resample to monitor this condition. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is at the top-end of the recommended limit.

view report



11 May 2021 Diag: Don Baldrige

VISUAL METAL



No corrective action is recommended at this time. The oil change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to metal particles present in this sample. Moderate concentration of visible metal present. All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



WATER



Area
PRESS
 Machine Id
0809SB01

Component
Rear Gearbox
 Fluid
KLUBER Klübersynth GH 6 ISO 320 (--- LTR)

DIAGNOSIS

Recommendation

We advise that you check for the source of water entry. We recommend you service the filters on this component. We recommend an early resample to monitor this condition.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil. There is a moderate concentration of water present in the oil.

Fluid Condition

The AN level is at the top-end of the recommended limit.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0668047	WC0730479	WC0541860
Sample Date	Client Info		17 Jul 2023	20 Apr 2023	15 Jul 2021
Machine Age	hrs	Client Info	0	0	80000
Oil Age	hrs	Client Info	0	0	8000
Oil Changed	Client Info		Not Changed	Not Changed	N/A
Sample Status			ABNORMAL	SEVERE	SEVERE

WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184		50	---	---
Iron	ppm	ASTM D5185m >200	20	15	8
Chromium	ppm	ASTM D5185m >15	<1	<1	<1
Nickel	ppm	ASTM D5185m >15	0	<1	<1
Titanium	ppm	ASTM D5185m	<1	0	0
Silver	ppm	ASTM D5185m	0	0	<1
Aluminum	ppm	ASTM D5185m >25	<1	0	0
Lead	ppm	ASTM D5185m >100	0	0	0
Copper	ppm	ASTM D5185m >200	2	2	<1
Tin	ppm	ASTM D5185m >25	<1	0	<1
Antimony	ppm	ASTM D5185m >5	---	---	0
Vanadium	ppm	ASTM D5185m	<1	<1	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	8	0	9
Barium	ppm	ASTM D5185m	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0
Manganese	ppm	ASTM D5185m	<1	0	<1
Magnesium	ppm	ASTM D5185m	4	<1	<1
Calcium	ppm	ASTM D5185m	2	<1	2
Phosphorus	ppm	ASTM D5185m 2450	2526	2089	1634
Zinc	ppm	ASTM D5185m	16	18	23
Sulfur	ppm	ASTM D5185m	235	0	0

CONTAMINANTS






	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >50	34	38	21
Sodium	ppm	ASTM D5185m	0	3	5
Potassium	ppm	ASTM D5185m >20	4	0	<1
Water	%	ASTM D6304 >0.2	▲ 0.564	---	---
ppm Water	ppm	ASTM D6304 >2000	▲ 5641.1	---	---

FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>20000	▲ 171801	185107	190491
Particles >6µm	ASTM D7647	>5000	▲ 63797	62276	65016
Particles >14µm	ASTM D7647	>640	▲ 3259	3578	2694
Particles >21µm	ASTM D7647	>160	▲ 621	778	485
Particles >38µm	ASTM D7647	>40	8	21	8
Particles >71µm	ASTM D7647	>10	0	0	0
Oil Cleanliness	ISO 4406 (c)	>21/19/16	▲ 25/23/19	25/23/19	25/23/19



OIL ANALYSIS REPORT




FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.955	2.65	2.20	▲ 4.014






VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	LIGHT
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	336.9	335	327	343

SAMPLE IMAGES		method	limit/base	current	history1	history2
---------------	--	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0668047 **Received** : 22 Aug 2023
Lab Number : 05930871 **Diagnosed** : 23 Aug 2023
Unique Number : 10616142 **Diagnostician** : Don Baldrige
Test Package : IND 2 (Additional Tests: KF, PQ, PrtCount)

FLAKEBOARD ARAUCO - MDF
 985 CORINTH RD
 MONCURE, NC
 US
 Contact: CHRISTOPHER JACKSON
 christopher.jackson@arauco.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)