


## **PROBLEM SUMMARY**

Area Compressor Machine Id ATLAS COPCO 2140 CO03 Component

Compressor Fluid ULTIMA 46 (15 GAL)

### COMPONENT CONDITION SUMMARY



### RECOMMENDATION

No corrective action is recommended at this time. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS							
Sample Status		ATTENTION	ABNORMAL	NORMAL			
Particles >4µm	ASTM D7647 >10	0000 🔺 <b>17607</b>	<u> </u>	8656			
Particles >6µm	ASTM D7647 >2	500 <b>A 4756</b>	▲ 5259	2064			
Oil Cleanliness	ISO 4406 (c) >20	)/18/15 🔺 <b>21/19/15</b>	<u> </u>	20/18/15			


Customer Id: FLAMONNC Sample No.: WC0806891 Lab Number: 05930873 Test Package: IND 2



To manage this report scan the QR code

*To discuss the diagnosis or test data:* Don Baldridge +1 <u>don.b505@comcast.net</u>

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com



### **RECOMMENDED ACTIONS**

There are no recommended actions for this sample.

### **HISTORICAL DIAGNOSIS**

### 24 Oct 2022 Diag: Doug Bogart



No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

#### 05 Jan 2021 Diag: Jonathan Hester



Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

27 Sep 2017 Diag: Don Baldridge




Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



view report

view repor







### **OIL ANALYSIS REPORT**

Area Compressor Machine Id ATLAS COPCO 2140 CO03 Component

Compressor Fluid ULTIMA 46 (15 GAL)

### DIAGNOSIS

### A Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

### Wear


All component wear rates are normal.

### Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.

### Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.




SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0806891	WC0668079	WC0541877
Sample Date		Client Info		08 Aug 2023	24 Oct 2022	05 Jan 2021
Machine Age	hrs	Client Info		0	0	80000
Oil Age	hrs	Client Info		0	0	12000
Oil Changed		Client Info		Not Changd	Not Changd	Not Changd
Sample Status				ATTENTION	ABNORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
PQ		ASTM D8184		18		
Iron	ppm	ASTM D5185m	>50	0	0	<1
Chromium	ppm	ASTM D5185m	>5	0	0	0
Nickel	ppm	ASTM D5185m		0	0	0
Titanium	ppm	ASTM D5185m		<1	0	0
Silver	ppm	ASTM D5185m		0	0	<1
Aluminum	ppm	ASTM D5185m	>15	0	0	0
Lead	ppm	ASTM D5185m	>65	0	0	0
Copper	ppm	ASTM D5185m	>65	<1	<1	3
Tin	ppm	ASTM D5185m	>10	0	0	<1
Antimony	ppm	ASTM D5185m				<1
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	<1
Barium	ppm	ASTM D5185m		0	<1	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	0	0
Magnesium	ppm	ASTM D5185m		2	0	0
Calcium	ppm	ASTM D5185m		0	0	0
Phosphorus	ppm	ASTM D5185m		62	11	25
Zinc	ppm	ASTM D5185m		0	0	0
Sulfur	ppm	ASTM D5185m		45	41	30
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>35	6	3	2
Sodium	ppm	ASTM D5185m		<1	0	0
Potassium	ppm	ASTM D5185m	>20	0	0	0
Water	%	ASTM D6304	>0.1	0.061		
ppm Water	ppm	ASTM D6304	>1000	614.2		
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	<b>A</b> 17607	<b>A</b> 22841	8656
Particles >6µm		ASTM D7647	>2500	<u> </u>	▲ 5259	2064
Particles >14µm		ASTM D7647	>320	283	225	200
Particles >21µm		ASTM D7647	>80	80	24	73
Particles >38μm		ASTM D7647	>20	5	0	6
Particles >71µm		ASTM D7647	>4	0	0	0
Oil Cleanliness		ISO 4406 (c)	>20/18/15	<u> </u>	<b>A</b> 22/20/15	20/18/15



# **OIL ANALYSIS REPORT**








FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.55	0.75	0.578
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	LIGHT	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445		53.8	50.4	53.4
SAMPLE IMAGES	S	method	limit/base	current	history1	history2
					瀬口	



Bottom





Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Certificate L2367