


## **OIL ANALYSIS REPORT**

### Sample Rating Trend



NORMAL



# KAESER 6987503

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

#### DIAGNOSIS

#### Recommendation

Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable.

#### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Jun2020 Oct	2020 Mar2021 Aug2021	Mar2022 Jun2022 Nov2022 Mar20	23 Aug2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC05930876	KC108107	KC104843
Sample Date		Client Info		15 Aug 2023	10 Mar 2023	07 Nov 2022
Machine Age	hrs	Client Info		34037	30250	27299
Oil Age	hrs	Client Info		0	6000	3000
Oil Changed		Client Info		N/A	Changed	Not Changd
Sample Status				NORMAL	ATTENTION	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	0
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	<1	<1	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	4	<1	<1
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	5	6	6
Tin	ppm	ASTM D5185m	>10	0	0	<1
Vanadium	ppm	ASTM D5185m		<1	<1	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	0	0	0
Molybdenum	ppm	ASTM D5185m		0	<1	0
Manganese	ppm	ASTM D5185m		<1	<1	0
Magnesium	ppm	ASTM D5185m	90	12	6	7
Calcium	ppm	ASTM D5185m	2	<1	0	0
Phosphorus	ppm	ASTM D5185m		4	<1	<1
Zinc	ppm	ASTM D5185m		34	7	10
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	0
Sodium	ppm	ASTM D5185m		4	<1	4
Potassium	ppm	ASTM D5185m	>20	<1	0	0
Water	%	ASTM D6304	>0.05	0.036	0.007	0.007
ppm Water	ppm	ASTM D6304	>500	364.7	79.7	72.3
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		844	1700	8980
Particles >6µm		ASTM D7647	>1300	165	651	<u>2244</u>
Particles >14μm		ASTM D7647	>80	13	<b>9</b> 2	<b>2</b> 09
Particles >21µm		ASTM D7647	>20	3	<b>△</b> 31	<b>△</b> 45
Particles >38μm		ASTM D7647	>4	1	1	1
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	17/15/11	<u>▲</u> 18/17/14	<u>△</u> 20/18/15
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
A : 1 N	1/011/	4 OTM   DOG 45	0.4			

Acid Number (AN)

mg KOH/g ASTM D8045 0.4


0.38

0.40

0.36



## **OIL ANALYSIS REPORT**



Certificate L2367

Test Package

: IND 2

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F:

Contact: Service Manager