

PROBLEM SUMMARY

Sample Rating Trend


ISO

Machine Id KAESER SM 12 5114127 (S/N 1599)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS								
Sample Status			ATTENTION	ABNORMAL	ABNORMAL			
Particles >6µm	ASTM D7647	>1300	<u> </u>	<u>^</u> 2793				
Particles >14μm	ASTM D7647	>80	133	△ 308				
Particles >21µm	ASTM D7647	>20	△ 37	<u></u> 119				
Oil Cleanliness	ISO 4406 (c)	>/17/13	20/18/14	21/19/15				

Customer Id: CENPARKY Sample No.: KCPA004032 Lab Number: 05930889 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

29 Sep 2022 Diag: Jonathan Hester

ISO



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



WATER



07 Feb 2022 Diag: Don Baldridge

We advise that you stop the unit and follow the water drain-off procedure for this component. The filter change at the time of sampling has been noted. We recommend an early resample in 500 hours to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. There is a moderate amount of visible silt present in the sample. Moderate concentration of visible dirt/debris present in the oil. There is a moderate concentration of water present in the oil. The AN level is acceptable for this fluid.



VIS DERRIS



14 Jun 2021 Diag: Angela Borella

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.





OIL ANALYSIS REPORT

Sample Rating Trend

ISO

KAESER SM 12 5114127 (S/N 1599)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of particulates present in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Mar2017 Sep2	017 Sep2018 Mar2019 Oct2	019 Jun2020 Jun2021 Feb2022 Sep20	022 Jul2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA004032	KCP46258	KCP38140
Sample Date		Client Info		20 Jul 2023	29 Sep 2022	07 Feb 2022
Machine Age	hrs	Client Info		451	50313	45859
Oil Age	hrs	Client Info		0	7546	4400
Oil Changed		Client Info		N/A	Changed	Not Changd
Sample Status				ATTENTION	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	<1	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	<1	0	<1
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	2	7	3
Tin	ppm	ASTM D5185m	>10	0	<1	<1
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	3
Barium	ppm	ASTM D5185m	90	5	0	2
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	0	0
Magnesium	ppm	ASTM D5185m	90	26	0	22
Calcium	ppm	ASTM D5185m	2	0	0	0
Phosphorus	ppm	ASTM D5185m		2	3	5
Zinc	ppm	ASTM D5185m		2	0	<1
Sulfur	ppm	ASTM D5185m		20203	19979	15989
CONTAMINANTS)	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	<1
Sodium	ppm	ASTM D5185m		6	0	4
Potassium	ppm	ASTM D5185m	>20	0	0	0
Water	%	ASTM D6304	>0.05	0.011	0.003	△ 0.433
ppm Water	ppm	ASTM D6304	>500	117.6	28.0	▲ 4330
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647		6979	10312	
Particles >6µm		ASTM D7647	>1300	<u>^</u> 2128	2793	
Particles >14µm		ASTM D7647	>80	133	▲ 308	
Particles >21µm		ASTM D7647	>20	△ 37	<u>119</u>	
Particles >38µm		ASTM D7647	>4	2	<u> </u>	
Particles >71µm		ASTM D7647	>3	1	1	
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>^</u> 20/18/14	<u>\$\text{\Delta}\$ 21/19/15</u>	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.39	0.38	0.35



OIL ANALYSIS REPORT



Test Package : IND 2 (Additional Tests: KF, PrtCount)

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Certificate L2367

T: F:

Contact: SERVICE MANAGER