




# OIL ANALYSIS REPORT

Sample Rating Trend

DEGRADATION



Area  
**PLOGER**  
Machine Id  
**6182 - PLOGER**  
Component  
**Transmission**  
Fluid  
**NOT GIVEN (--- GAL)**

## DIAGNOSIS

### Recommendation

We recommend that you drain the fluid and perform a filter service on this component if not already done. We recommend an early resample to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample.

### Wear

All component wear rates are normal.

### Contamination

There is a moderate amount of visible silt present in the sample.

### Fluid Condition

The AN level is above the recommended limit. The fluid is no longer serviceable.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0843160</b>	WC0728478	---
Sample Date	Client Info		<b>05 Jul 2023</b>	30 Jul 2022	---
Machine Age	mls	Client Info	<b>619766</b>	494290	---
Oil Age	mls	Client Info	<b>0</b>	0	---
Oil Changed	Client Info		<b>N/A</b>	N/A	---
Sample Status			<b>ABNORMAL</b>	ABNORMAL	---

## WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>200	<b>99</b>	69	---
Chromium	ppm	ASTM D5185m	>10	<b>2</b>	1	---
Nickel	ppm	ASTM D5185m		<b>&lt;1</b>	3	---
Titanium	ppm	ASTM D5185m		<b>&lt;1</b>	<1	---
Silver	ppm	ASTM D5185m		<b>0</b>	0	---
Aluminum	ppm	ASTM D5185m	>50	<b>30</b>	▲ 29	---
Lead	ppm	ASTM D5185m	>50	<b>0</b>	<1	---
Copper	ppm	ASTM D5185m	>200	<b>47</b>	35	---
Tin	ppm	ASTM D5185m	>10	<b>&lt;1</b>	<1	---
Vanadium	ppm	ASTM D5185m		<b>0</b>	<1	---
Cadmium	ppm	ASTM D5185m		<b>0</b>	0	---

## ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		<b>139</b>	189	---
Barium	ppm	ASTM D5185m		<b>0</b>	2	---
Molybdenum	ppm	ASTM D5185m		<b>1</b>	4	---
Manganese	ppm	ASTM D5185m		<b>25</b>	21	---
Magnesium	ppm	ASTM D5185m		<b>0</b>	3	---
Calcium	ppm	ASTM D5185m		<b>193</b>	235	---
Phosphorus	ppm	ASTM D5185m		<b>1321</b>	1337	---
Zinc	ppm	ASTM D5185m		<b>9</b>	18	---
Sulfur	ppm	ASTM D5185m		<b>1115</b>	1275	---

## CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>50	<b>20</b>	▲ 74	---
Sodium	ppm	ASTM D5185m		<b>3</b>	4	---
Potassium	ppm	ASTM D5185m	>20	<b>&lt;1</b>	2	---
Water	%	ASTM D6304	>0.1	<b>0.096</b>	▲ 0.102	---
ppm Water	ppm	ASTM D6304	>1000	<b>968.9</b>	▲ 1023.7	---





## FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	---	▲ 249210	---
Particles >6µm	ASTM D7647	>2500	---	▲ 28456	---
Particles >14µm	ASTM D7647	>320	---	▲ 699	---
Particles >21µm	ASTM D7647	>80	---	66	---
Particles >38µm	ASTM D7647	>20	---	0	---
Particles >71µm	ASTM D7647	>4	---	0	---
Oil Cleanliness	ISO 4406 (c)	>20/18/15	---	▲ 25/22/17	---

## FLUID DEGRADATION

	method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045		▲ <b>5.01</b>	▲ 4.69	---

# OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	▲ MODER	---
Debris	scalar	*Visual	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.1	NEG	---
Free Water	scalar	*Visual		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	55.6	▲ 55.4	---
Visc @ 100°C	cSt	ASTM D445	9.7	9.7	---
Viscosity Index (VI)	Scale	ASTM D2270	160	161	---





### SAMPLE IMAGES

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

no image

no image

### GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0843160 **Received** : 22 Aug 2023  
**Lab Number** : 05931525 **Diagnosed** : 24 Aug 2023  
**Unique Number** : 10616796 **Diagnostician** : Jonathan Hester  
**Test Package** : MOB 2 ( Additional Tests: KF, KV100, PrtCount, VI )

**BASF - GIANNA CREDAROLI**  
 500 WHITE PLAINS RD  
 TARRYTOWN, NY  
 US 10591  
 Contact: GIANNA CREDAROLI  
 gianna.credaroli@basf.com

Certificate L2367  
 To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)