



PROBLEM SUMMARY


Area **PEMBROOK PLANT** Machine Id **C-4113 (S/N 10241K85567414)** Component

Refrigeration Compressor Fluid SUMMIT PGI 100 (250 GAL)

COMPONENT CONDITION SUMMARY







RECOMMENDATION

No corrective action is recommended at this time. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status				ATTENTION	ABNORMAL	NORMAL
Water	%	ASTM D6304	>0.01	0.047	0.00	0.003
ppm Water	ppm	ASTM D6304	>100	470.7	0.00	33.9
Particles >4µm		ASTM D7647	>10000	🔺 15831	<u> </u>	3522
Particles >6µm		ASTM D7647	>2500	A 3075	6566	717
Oil Cleanliness		ISO 4406 (c)	>20/18/15	<u> </u>	<u> </u>	19/17/13

Customer Id: TARPEMB Sample No.: TO90002259 Lab Number: 05931574 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

15 Mar 2023 Diag: Angela Borella



Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

08 Mar 2022 Diag: Don Baldridge



Resample at the next service interval to monitor.All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



view repor



30 Nov 2021 Diag: Doug Bogart



No corrective action is recommended at this time. Resample at the next service interval to monitor.All component wear rates are normal. There is a trace of moisture present in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.







OIL ANALYSIS REPORT

Sample Rating Trend

WATER

Area **PEMBROOK PLANT** Machine Id **C-4113 (S/N 10241K85567414)** Component

Refrigeration Compressor Fluid SUMMIT PGI 100 (250 GAL)

DIAGNOSIS

A Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. There is a trace of moisture present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		TO90002259		TO90000830
Sample Date		Client Info		15 Aug 2023	15 Mar 2023	08 Mar 2022
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ATTENTION		NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>8	<1	<1	0
Chromium	ppm	ASTM D5185m	>2	0	0	0
Nickel	ppm	ASTM D5185m		0	<1	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m	>3	0	1	<1
Lead	ppm	ASTM D5185m	>2	0	0	0
Copper	ppm	ASTM D5185m		<1	0	0
Tin	ppm	ASTM D5185m	>4	1	<1	<1
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
	ρρπ					-
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	3
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	<1	0
Manganese	ppm	ASTM D5185m		<1	0	0
Magnesium	ppm	ASTM D5185m		2	6	0
Calcium	ppm	ASTM D5185m		39	38	40
Phosphorus	ppm	ASTM D5185m		458	343	33
Zinc	ppm	ASTM D5185m		0	7	<1
Sulfur	ppm	ASTM D5185m		149	102	41
CONTAMINANTS	5	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	5	5	5
Sodium	ppm	ASTM D5185m		1	0	0
Potassium	ppm	ASTM D5185m	>20	1	<1	0
Water	%	ASTM D6304	>0.01	6 0.047	0.00	0.003
ppm Water	ppm	ASTM D6304	>100	470.7	0.00	33.9
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	A 15831	A 22600	3522
Particles >6µm		ASTM D7647	>2500	<u> </u>	▲ 6566	717
Particles >14µm		ASTM D7647	>320	115	▲ 324	45
Particles >21µm		ASTM D7647	>80	24	62	9
Particles >38µm		ASTM D7647	>20	1	1	0
Particles >71µm		ASTM D7647	>4	0	0	0
Oil Cleanliness		ISO 4406 (c)	>20/18/15	A 21/19/14	2 2/20/16	19/17/13
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN) :43:06) Rev: 1	mg KOH/g	ASTM D974		0.015	0.056 Submitted By: EF	0.07

Report Id: TARPEMB [WUSCAR] 05931574 (Generated: 08/24/2023 11:43:06) Rev: 1

Submitted By: ERIC THORNTON



OIL ANALYSIS REPORT



VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	VLITE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.01	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	100	107	105	103
Visc @ 100°C	cSt	ASTM D445	18.6	17.6	17.0	16.1
Viscosity Index (VI)	Scale	ASTM D2270	185	181	176	167
SAMPLE IMAGES	6	method	limit/base	current	history1	history2
Color					12	





