



Area
EDWARD PLANT
Machine Id
C-2161 (S/N XC0342)

Component
Refrigeration Compressor
Fluid
TULCO LUBSOIL SYN RL WI 100 (250 GAL)



COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

No corrective action is recommended at this time.
Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	NORMAL	NORMAL
Particles >4µm	ASTM D7647	>10000	▲ 22788	5224	541
Particles >6µm	ASTM D7647	>2500	▲ 3522	933	146
Oil Cleanliness	ISO 4406 (c)	>20/18/15	▲ 22/19/14	20/17/12	16/14/10

Customer Id: TAREDWA
Sample No.: TO90002230
Lab Number: 05931576
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Don Baldrige +1
don.b505@comcast.net

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.

HISTORICAL DIAGNOSIS

15 Mar 2023 Diag: Doug Bogart

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The condition of the oil is acceptable for the time in service. Insufficient sample was received to conduct all the routine laboratory tests.

view report



30 Nov 2022 Diag: Doug Bogart

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



07 Sep 2022 Diag: Doug Bogart

NORMAL




Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



Area
EDWARD PLANT
 Machine Id
C-2161 (S/N XC0342)
 Component
Refrigeration Compressor
 Fluid
TULCO LUBSOIL SYN RL WI 100 (250 GAL)



DIAGNOSIS

Recommendation
 No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear
 All component wear rates are normal.

Contamination
 There is a high amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition
 The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	TO90002230	TO90002330	TO90002357
Sample Date	Client Info	14 Aug 2023	15 Mar 2023	30 Nov 2022
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		ABNORMAL	NORMAL	NORMAL

WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >8	8	7	2
Chromium	ppm	ASTM D5185m >2	0	0	<1
Nickel	ppm	ASTM D5185m	0	<1	<1
Titanium	ppm	ASTM D5185m	0	0	<1
Silver	ppm	ASTM D5185m >2	0	0	<1
Aluminum	ppm	ASTM D5185m >3	0	1	0
Lead	ppm	ASTM D5185m >2	0	0	2
Copper	ppm	ASTM D5185m >8	1	0	<1
Tin	ppm	ASTM D5185m >4	3	1	<1
Vanadium	ppm	ASTM D5185m	0	<1	<1
Cadmium	ppm	ASTM D5185m	0	0	<1

ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	0	0	2
Barium	ppm	ASTM D5185m	0	0	0
Molybdenum	ppm	ASTM D5185m	0	<1	<1
Manganese	ppm	ASTM D5185m	<1	<1	<1
Magnesium	ppm	ASTM D5185m	2	5	11
Calcium	ppm	ASTM D5185m	41	45	4
Phosphorus	ppm	ASTM D5185m 1500	766	667	174
Zinc	ppm	ASTM D5185m	0	10	4
Sulfur	ppm	ASTM D5185m	99	63	0

CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >15	3	2	1
Sodium	ppm	ASTM D5185m	1	0	7
Potassium	ppm	ASTM D5185m >20	1	1	26
Water	%	ASTM D6304 >2.26	0.039	0.056	0.075
ppm Water	ppm	ASTM D6304 >22600	395.6	564.4	751.2

FLUID CLEANLINESS


method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >10000	▲ 22788	5224	541
Particles >6µm	ASTM D7647 >2500	▲ 3522	933	146
Particles >14µm	ASTM D7647 >320	85	27	10
Particles >21µm	ASTM D7647 >80	12	7	3
Particles >38µm	ASTM D7647 >20	0	0	0
Particles >71µm	ASTM D7647 >4	0	0	0
Oil Cleanliness	ISO 4406 (c) >20/18/15	▲ 22/19/14	20/17/12	16/14/10

FLUID DEGRADATION


method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D974 0.04	0.031	---	0.078

OIL ANALYSIS REPORT


▲ Particle Trend




Water




Viscosity @ 100°C



Water



Viscosity @ 100°C




VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>2.26	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	97	104	106
Visc @ 100°C	cSt	ASTM D445	17.5	17.9	18.2
Viscosity Index (VI)	Scale	ASTM D2270	198	190	191

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------


Color




Bottom

GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



▲ Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : TO90002230 **Received** : 22 Aug 2023
Lab Number : 05931576 **Diagnosed** : 24 Aug 2023
Unique Number : 10616847 **Diagnostician** : Don Baldrige
Test Package : IND 2 (Additional Tests: KV100, PrtCount, VI)

TARGA RESOURCES - EDWARD
 1757 COUNTY ROAD 250
 MIDKIFF, TX
 US 79755
 Contact: BRANDON CERVANTES
 bcervantes@targaresources.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: