

# **PROBLEM SUMMARY**

### Area **PEMBROOK PLANT** Machine Id **C-4112 (S/N 10241H85546043)** Component

Refrigeration Compressor Fluid SUMMIT PGI 100 (250 GAL)

### COMPONENT CONDITION SUMMARY



### RECOMMENDATION

No corrective action is recommended at this time. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS								
Sample Status				MARGINAL	NORMAL	NORMAL		
Water	%	ASTM D6304	>0.01	<b>0.042</b>	0.00	0.006		
ppm Water	ppm	ASTM D6304	>100	<b>428.2</b>	0.00	61.2		

Customer Id: TARPEMB Sample No.: TO90002258 Lab Number: 05931577 Test Package: IND 2



To manage this report scan the QR code

*To discuss the diagnosis or test data:* Don Baldridge +1 <u>don.b505@comcast.net</u>

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com



### **RECOMMENDED ACTIONS**

There are no recommended actions for this sample.

### HISTORICAL DIAGNOSIS

#### 15 Mar 2023 Diag: Angela Borella



Resample at the next service interval to monitor.All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

#### 08 Mar 2022 Diag: Don Baldridge



Resample at the next service interval to monitor.All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



view repor





30 Nov 2021 Diag: Doug Bogart

No corrective action is recommended at this time. Resample at the next service interval to monitor.All component wear rates are normal. There is a trace of moisture present in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





# **OIL ANALYSIS REPORT**

Sample Rating Trend

### Area **PEMBROOK PLANT** Machine Id **C-4112 (S/N 10241H85546043)** Component

Refrigeration Compressor Fluid SUMMIT PGI 100 (250 GAL)

# DIAGNOSIS

### A Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

## Contamination

There is a trace of moisture present in the oil. The amount and size of particulates present in the system are acceptable.

### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		TO90002258	TO90002337	TO9000854
Sample Date		Client Info		15 Aug 2023	15 Mar 2023	08 Mar 2022
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				MARGINAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>8	<1	<1	0
Chromium	ppm	ASTM D5185m	>2	0	0	0
Nickel	ppm	ASTM D5185m		0	<1	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m	>3	0	1	<1
Lead	ppm	ASTM D5185m	>2	0	0	0
Copper	ppm	ASTM D5185m	>8	<1	0	0
Tin	ppm	ASTM D5185m	>4	1	<1	<1
Antimony	ppm	ASTM D5185m				<1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	3
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	<1	0
Manganese	ppm	ASTM D5185m		<1	0	0
Magnesium	ppm	ASTM D5185m		<1	2	0
Calcium	ppm	ASTM D5185m		39	50	33
Phosphorus	ppm	ASTM D5185m		389	117	23
Zinc	ppm	ASTM D5185m		0	7	2
Sulfur	ppm	ASTM D5185m		103	123	39
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	6	6	6
Sodium	ppm	ASTM D5185m		1	0	0
Potassium	ppm	ASTM D5185m	>20	1	<1	0
Water	%	ASTM D6304	>0.01	<u> </u>	0.00	0.006
ppm Water	ppm	ASTM D6304	>100	<b>428.2</b>	0.00	61.2
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	8476	7283	6276
Particles >6µm		ASTM D7647	>2500	1474	1675	1355
Particles >14µm		ASTM D7647	>320	35	53	56
Particles >21µm		ASTM D7647	>80	9	11	15
Particles >38µm		ASTM D7647	>20	0	0	2
Particles >71µm		ASTM D7647	>4	0	0	2
Oil Cleanliness		ISO 4406 (c)	>20/18/15	20/18/12	20/18/13	20/18/13
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974		0.015	0.058	0.041

Report Id: TARPEMB [WUSCAR] 05931577 (Generated: 08/24/2023 11:43:23) Rev: 1

Submitted By: ERIC THORNTON

WATER



# **OIL ANALYSIS REPORT**



VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.01	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	100	106	103	102
Visc @ 100°C	cSt	ASTM D445	18.6	17.3	16.2	16.1
Viscosity Index (VI)	Scale	ASTM D2270	185	179	169	169
SAMPLE IMAGES		method	limit/base	current	history1	history2
Color						



ar6/7/

ug28/19