

PROBLEM SUMMARY

Sample Rating Trend


ISO

EDWARD PLANT Machine Id C-2162 (S/N XC0600)

Refrigeration Compressor

TULCO LUBSOIL SYN RL WI 100 (250 GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS								
Sample Status			ABNORMAL	NORMAL	ABNORMAL			
Particles >4µm	ASTM D7647	>10000	4 30352	5264	<u>^</u> 21627			
Particles >6µm	ASTM D7647	>2500	6049	1355	4264			
Oil Cleanliness	ISO 4406 (c)	>20/18/15	22/20/15	20/18/13	<u>^</u> 22/19/15			

Customer Id: TAREDWA Sample No.: TO90002251 Lab Number: 05931578 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

30 Nov 2022 Diag: Doug Bogart

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



07 Sep 2022 Diag: Doug Bogart

ISO



No corrective action is recommended at this time. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



02 Mar 2022 Diag: Angela Borella

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend



EDWARD PLANT C-2162 (S/N XC0600)

Refrigeration Compressor

TULCO LUBSOIL SYN RL WI 100 (250 GAL)

Recommendation No corrective action is recommended at this time. Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

DIAGNOSIS

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION n	nethod	limit/base	current	h
	u/2018 Feb201		Mw2021 Sep2021 Mw2022	Nov2022
SIS REPORT				

Sample Number		Client Info		TO90002251	TO90002358	TO9012503
Sample Date		Client Info		14 Aug 2023	30 Nov 2022	07 Sep 2022
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	Not Changd
Sample Status				ABNORMAL	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>8	6	2	7
Chromium	ppm	ASTM D5185m	>2	0	<1	0
Nickel	ppm	ASTM D5185m		0	<1	0
Titanium	ppm	ASTM D5185m		0	<1	0
Silver	ppm	ASTM D5185m	>2	0	<1	0
Aluminum	ppm	ASTM D5185m	>3	0	0	<1
Lead	ppm	ASTM D5185m	>2	0	2	0
Copper	ppm	ASTM D5185m	>8	1	<1	0
Tin	ppm	ASTM D5185m	>4	3	1	2
Antimony	ppm	ASTM D5185m				
Vanadium	ppm	ASTM D5185m		0	<1	0
Cadmium	ppm	ASTM D5185m		0	<1	0
	ρρ			-		-
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	2	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	<1	<1
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m		1	10	0
Calcium	ppm	ASTM D5185m		44	8	45
Phosphorus	ppm	ASTM D5185m	1500	683	102	263
Zinc	ppm	ASTM D5185m		0	6	8
Sulfur	ppm	ASTM D5185m		114	0	72
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	4	1	2
Sodium	ppm	ASTM D5185m		1	6	<1
Potassium	ppm	ASTM D5185m	>20	<1	25	0
Water	%	ASTM D6304	>2.26	0.033	0.103	0.019
ppm Water	ppm	ASTM D6304	>22600	333.6	1037.8	197.7
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	30352	5264	<u> </u>
Particles >6µm		ASTM D7647	>2500	6049	1355	4264
Particles >14µm		ASTM D7647	>320	219	80	300
Particles >21µm		ASTM D7647	>80	42	14	73
Particles >38µm		ASTM D7647	>20	1	1	1
Particles >71µm		ASTM D7647	>4	0	0	0
Oil Cleanliness		ISO 4406 (c)	>20/18/15	<u>^</u> 22/20/15	20/18/13	<u>22/19/15</u>
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974	0.04	0.03	0.072	0.028
(, 114)						



OIL ANALYSIS REPORT



* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: