



Area
REBEL 1
Machine Id
FRICK C-162 - REBEL 1
Component
Refrigeration Compressor
Fluid
TULCO LUBSOIL SYN RL WI 100 (250 GAL)



COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

No corrective action is recommended at this time.
Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status			ATTENTION	NORMAL	MARGINAL
Particles >4µm	ASTM D7647	>10000	▲ 10851	1831	7858
Particles >6µm	ASTM D7647	>2500	▲ 2538	463	1270
Oil Cleanliness	ISO 4406 (c)	>20/18/15	▲ 21/19/14	18/16/12	20/17/13

Customer Id: ENEGAR
Sample No.: TO90002192
Lab Number: 05931587
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Doug Bogart +1 (800)237-1369 x4016
dougb@wearcheckusa.com

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

15 Mar 2023 Diag: Don Baldrige

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



02 Mar 2022 Diag: Don Baldrige

WATER



No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. There is a trace of moisture present in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



01 Dec 2021 Diag: Doug Bogart

WATER




No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. There is a trace of moisture present in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



Area
REBEL 1
Machine Id
FRICK C-162 - REBEL 1
Component
Refrigeration Compressor
Fluid
TULCO LUBSOIL SYN RL WI 100 (250 GAL)



DIAGNOSIS

Recommendation
No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear
All component wear rates are normal.

Contamination
There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	TO90002192	TO90002312	TO90000049
Sample Date	Client Info	14 Aug 2023	15 Mar 2023	02 Mar 2022
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		ATTENTION	NORMAL	MARGINAL

WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >8	22	10	1
Chromium	ppm	ASTM D5185m >2	0	0	0
Nickel	ppm	ASTM D5185m	0	<1	0
Titanium	ppm	ASTM D5185m	0	0	0
Silver	ppm	ASTM D5185m >2	0	0	<1
Aluminum	ppm	ASTM D5185m >3	0	1	<1
Lead	ppm	ASTM D5185m >2	0	0	0
Copper	ppm	ASTM D5185m >8	<1	0	0
Tin	ppm	ASTM D5185m >4	1	<1	<1
Antimony	ppm	ASTM D5185m	---	---	3
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	0	0	3
Barium	ppm	ASTM D5185m	0	0	0
Molybdenum	ppm	ASTM D5185m	0	1	0
Manganese	ppm	ASTM D5185m	<1	<1	0
Magnesium	ppm	ASTM D5185m	<1	<1	0
Calcium	ppm	ASTM D5185m	2	4	0
Phosphorus	ppm	ASTM D5185m 1500	702	350	396
Zinc	ppm	ASTM D5185m	12	5	0
Sulfur	ppm	ASTM D5185m	16	11	0

CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >15	3	2	1
Sodium	ppm	ASTM D5185m	9	10	6
Potassium	ppm	ASTM D5185m >20	<1	<1	0
Water	%	ASTM D6304 >2.26	0.028	0.006	▲ 0.013
ppm Water	ppm	ASTM D6304 >22600	284.6	63.9	▲ 137.4

FLUID CLEANLINESS


method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >10000	▲ 10851	1831	7858
Particles >6µm	ASTM D7647 >2500	▲ 2538	463	1270
Particles >14µm	ASTM D7647 >320	93	25	44
Particles >21µm	ASTM D7647 >80	24	8	10
Particles >38µm	ASTM D7647 >20	2	1	0
Particles >71µm	ASTM D7647 >4	0	1	0
Oil Cleanliness	ISO 4406 (c) >20/18/15	▲ 21/19/14	18/16/12	20/17/13

FLUID DEGRADATION


method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D974 0.04	0.016	0.028	0.015

OIL ANALYSIS REPORT


▲ Particle Trend




Water




Viscosity @ 100°C



Water




Viscosity @ 100°C



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>2.26	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	97	102	99.3
Visc @ 100°C	cSt	ASTM D445	17.55	16.1	15.0
Viscosity Index (VI)	Scale	ASTM D2270	198	169	158

SAMPLE IMAGES




GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



▲ Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : TO90002192 **Received** : 22 Aug 2023
Lab Number : 05931587 **Diagnosed** : 25 Aug 2023
Unique Number : 10616858 **Diagnostician** : Doug Bogart
Test Package : IND 2 (Additional Tests: KV100, PrtCount, VI)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

ENERGY TRANSFER - REBEL
 13788 TX-158
 GARDEN CITY, TX
 US 79739
 Contact: BOBBY POSEY
 bobby.posey@energytransfer.com
 T: (432)270-4842
 F: