


PROBLEM SUMMARY

Sample Rating Trend




WATER




Area
DRIVER PLANT
Machine Id
C-1162 (S/N XC-0250)
Component
Refrigeration Compressor
Fluid
SUMMIT PGI 100 (250 GAL)

COMPONENT CONDITION SUMMARY

▲ Particle Trend



▲ Water



RECOMMENDATION

Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status				ATTENTION	ABNORMAL	NORMAL
Water	%	ASTM D6304	>0.01	▲ 0.079	0.003	0.008
ppm Water	ppm	ASTM D6304	>100	▲ 793.0	36.2	85.7
Particles >4µm		ASTM D7647	>10000	▲ 15490	▲ 99177	5345
Particles >6µm		ASTM D7647	>2500	▲ 3352	▲ 44872	1207
Oil Cleanliness		ISO 4406 (c)	>20/18/15	▲ 21/19/14	▲ 24/23/18	20/17/13

Customer Id: TARDRIV
Sample No.: TO90002275
Lab Number: 05931615
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Angela Borella +1 800-237-1369
angela.borella@wearcheckusa.com

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

16 Mar 2023 Diag: Doug Bogart

ISO



We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



08 Mar 2022 Diag: Don Baldrige

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



01 Dec 2021 Diag: Doug Bogart

WATER




No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. There is a trace of moisture present in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



Area
DRIVER PLANT
 Machine Id
C-1162 (S/N XC-0250)
 Component
Refrigeration Compressor
 Fluid
SUMMIT PGI 100 (250 GAL)



DIAGNOSIS

Recommendation
 Resample at the next service interval to monitor.

Wear
 All component wear rates are normal.

Contamination
 There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. There is a trace of moisture present in the oil.

Fluid Condition
 The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	TO90002275	TO90002376	TO90000862
Sample Date	Client Info	15 Aug 2023	16 Mar 2023	08 Mar 2022
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		ATTENTION	ABNORMAL	NORMAL

WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >8	2	6	4
Chromium	ppm	ASTM D5185m >2	0	<1	0
Nickel	ppm	ASTM D5185m	0	<1	0
Titanium	ppm	ASTM D5185m	0	0	0
Silver	ppm	ASTM D5185m >2	0	0	<1
Aluminum	ppm	ASTM D5185m >3	0	1	<1
Lead	ppm	ASTM D5185m >2	0	0	0
Copper	ppm	ASTM D5185m >8	<1	0	0
Tin	ppm	ASTM D5185m >4	1	1	1
Antimony	ppm	ASTM D5185m	---	---	<1
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	0	0	2
Barium	ppm	ASTM D5185m	0	0	0
Molybdenum	ppm	ASTM D5185m	0	<1	0
Manganese	ppm	ASTM D5185m	<1	<1	0
Magnesium	ppm	ASTM D5185m	<1	2	0
Calcium	ppm	ASTM D5185m	6	25	17
Phosphorus	ppm	ASTM D5185m	1111	345	427
Zinc	ppm	ASTM D5185m	0	12	5
Sulfur	ppm	ASTM D5185m	8	30	16

CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >15	2	2	<1
Sodium	ppm	ASTM D5185m	2	0	0
Potassium	ppm	ASTM D5185m >20	1	1	0
Water	%	ASTM D6304 >0.01	▲ 0.079	0.003	0.008
ppm Water	ppm	ASTM D6304 >100	▲ 793.0	36.2	85.7






FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >10000	▲ 15490	▲ 99177	5345
Particles >6µm	ASTM D7647 >2500	▲ 3352	▲ 44872	1207
Particles >14µm	ASTM D7647 >320	103	▲ 2344	43
Particles >21µm	ASTM D7647 >80	20	▲ 1017	9
Particles >38µm	ASTM D7647 >20	0	15	0
Particles >71µm	ASTM D7647 >4	0	0	0
Oil Cleanliness	ISO 4406 (c) >20/18/15	▲ 21/19/14	▲ 24/23/18	20/17/13

FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g ASTM D974	0.014	0.056	0.056


OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.01	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	100	107	105
Visc @ 100°C	cSt	ASTM D445	18.6	18.9	18.4
Viscosity Index (VI)	Scale	ASTM D2270	185	198	195

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : TO90002275 **Received** : 22 Aug 2023
Lab Number : 05931615 **Diagnosed** : 24 Aug 2023
Unique Number : 10616886 **Diagnostician** : Angela Borella
Test Package : IND 2 (Additional Tests: KV100, PrtCount, VI)

TARGA RESOURCES - DRIVER
 38003 FM 1379
 MIDLAND, TX
 US 78706
 Contact: JUSTIN WADELL
 jwaddell@targaresources.com
 T: (432)967-7967
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)