


PROBLEM SUMMARY

Area DRIVER PLANT Machine Id C-1163 (S/N XC-8365) Component

Refrigeration Compressor Fluid SUMMIT PGI 100 (250 GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status				MARGINAL	ATTENTION	NORMAL			
Water	%	ASTM D6304	>0.01	0.067	0.003	0.006			
ppm Water	ppm	ASTM D6304	>100	🔺 679.4	34.8	65.4			


Customer Id: TARDRIV Sample No.: TO90002276 Lab Number: 05931616 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Angela Borella +1 800-237-1369 angela.borella@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com



RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

16 Mar 2023 Diag: Doug Bogart



No corrective action is recommended at this time. Resample at the next service interval to monitor.All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



08 Mar 2022 Diag: Don Baldridge



 \checkmark

Resample at the next service interval to monitor.All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





01 Dec 2021 Diag: Don Baldridge



No corrective action is recommended at this time. Resample at the next service interval to monitor.All component wear rates are normal. There is a trace of moisture present in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend

WATER

Area DRIVER PLANT Machine Id C-1163 (S/N XC-8365)

Component Refrigeration Compressor Fluid SUMMIT PGI 100 (250 GAL)

DIAGNOSIS

A Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a light concentration of water present in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


		1a/2019 Aug2	019 Aug2019 Mar2020	Aug2020 Mar2021 Sep2021 Mar	2022 Aug202	
SAMPLE INFOR	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		TO90002276	TO90002377	TO90000865
Sample Date		Client Info		15 Aug 2023	16 Mar 2023	08 Mar 2022
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				MARGINAL	ATTENTION	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
ron	ppm	ASTM D5185m	>8	5	3	0
Chromium	ppm	ASTM D5185m	>2	0	0	0
Nickel	ppm	ASTM D5185m		0	<1	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m	>3	0	1	<1
_ead	ppm	ASTM D5185m	>2	0	0	0
Copper	ppm	ASTM D5185m	>8	<1	0	0
Γin	ppm	ASTM D5185m	>4	1	<1	<1
Antimony	ppm	ASTM D5185m				<1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	2
Barium	ppm	ASTM D5185m		0	0	0
Volybdenum	ppm	ASTM D5185m		0	<1	0
Vanganese	ppm	ASTM D5185m		<1	0	0
Vagnesium	ppm	ASTM D5185m		<1	<1	0
Calcium	ppm	ASTM D5185m		4	5	4
Phosphorus	ppm	ASTM D5185m		1242	1534	1419
Zinc	ppm	ASTM D5185m		0	2	0
Sulfur	ppm	ASTM D5185m		3	<1	0
CONTAMINANTS	S	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	2	1	<1
Sodium	ppm	ASTM D5185m		1	0	0
Potassium	ppm	ASTM D5185m	>20	<1	<1	0
Water	%	ASTM D6304	>0.01	0.067	0.003	0.006
opm Water	ppm	ASTM D6304	>100	6 79.4	34.8	65.4
FLUID CLEANLIN	NESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	3066	9332	1506
Particles >6µm		ASTM D7647	>2500	798	<u> </u>	330
Particles >14µm		ASTM D7647	>320	56	103	18
Particles >21µm		ASTM D7647	>80	14	18	6
Particles >38µm		ASTM D7647	>20	0	0	0
Particles >71µm		ASTM D7647	>4	0	0	0
Oil Cleanliness		ISO 4406 (c)	>20/18/15	19/17/13	▲ 20/19/14	18/16/11
FLUID DEGRAD	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974		0.014	0.014 ubmitted By: EF	


Report Id: TARDRIV [WUSCAR] 05931616 (Generated: 08/24/2023 15:18:36) Rev: 1


Submitted By: ERIC THORNTON



OIL ANALYSIS REPORT







105

95

90

8

CSt (40°C) cSt (40°C) cSt

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.01	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	100	106	102	99.2
Visc @ 100°C	cSt	ASTM D445	18.6	18.9	17.9	14.9
Viscosity Index (VI)	Scale	ASTM D2270	185	199	194	157
SAMPLE IMAGES		method	limit/base	current	history1	history2
Color						

Bottom

