




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id
CATERPILLAR GM02
 Component
Biogas Engine
 Fluid
Q8 G5 MAHLER 40 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0836333	WC0836326	WC0836332
Sample Date	Client Info		21 Aug 2023	18 Aug 2023	18 Aug 2023
Machine Age	hrs	Client Info	64723	64660	64661
Oil Age	hrs	Client Info	63	156	1
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			NORMAL	SEVERE	NORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>4.0	<1.0	<1.0	<1.0
Glycol	WC Method		NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >45	42	97	36
Chromium	ppm	ASTM D5185m >2	<1	2	<1
Nickel	ppm	ASTM D5185m >2	0	<1	<1
Titanium	ppm	ASTM D5185m	0	0	0
Silver	ppm	ASTM D5185m >5	0	0	0
Aluminum	ppm	ASTM D5185m >10	2	3	2
Lead	ppm	ASTM D5185m >5	0	<1	<1
Copper	ppm	ASTM D5185m >14	2	3	<1
Tin	ppm	ASTM D5185m >13	<1	<1	<1
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0
Barium	ppm	ASTM D5185m	0	0	0
Molybdenum	ppm	ASTM D5185m	0	<1	<1
Manganese	ppm	ASTM D5185m	1	1	<1
Magnesium	ppm	ASTM D5185m	4	3	3
Calcium	ppm	ASTM D5185m	1393	1429	1374
Phosphorus	ppm	ASTM D5185m	385	382	365
Zinc	ppm	ASTM D5185m	426	460	436
Sulfur	ppm	ASTM D5185m	2301	2336	2175

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >200	46	65	10
Sodium	ppm	ASTM D5185m	2	0	0
Potassium	ppm	ASTM D5185m >20	0	<1	<1

INFRA-RED




	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	0	0	0
Nitration	Abs/cm	*ASTM D7624 >20	4.8	5.2	4.2
Sulfation	Abs/.1mm	*ASTM D7415 >30	15.3	15.7	14.8

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414 >25	9.4	9.9	8.7
Acid Number (AN)	mg KOH/g	ASTM D8045	0.49	0.835	0.39
Base Number (BN)	mg KOH/g	ASTM D2896	6.64	6.57	6.83











OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	13.1	13.1	13.1

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0836333 **Received** : 22 Aug 2023
Lab Number : 05931657 **Diagnosed** : 24 Aug 2023
Unique Number : 10616928 **Diagnostician** : Don Baldrige
Test Package : MOB 2

OAK GROVE KS
 1150 E 700TH AVE
 ARCADIA, KS
 US 66711
 Contact: KALEB WEAVER
 kaleb.weaver@cubedistrictenergy.com
 T:
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)