

OIL ANALYSIS REPORT

CAPTIS ENERGY ENG 2 (S/N 1251397)

Component Natural Gas Engine Fluid Q8G8 (--- GAL)

DIAGNOSIS

A Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

🔺 Wear


The tin level is abnormal. All other component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition


The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0835682	WC0835631	WC0835628
Sample Date		Client Info		21 Aug 2023	24 Jul 2023	18 Jul 2023
Machine Age	hrs	Client Info		46000	45476	45423
Oil Age	hrs	Client Info		3975	3451	3398
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	13	7	7
Chromium	ppm	ASTM D5185m	>4	1	<1	<1
Nickel	ppm	ASTM D5185m	>2	<1	0	0
Titanium	ppm	ASTM D5185m		<1	<1	0
Silver	ppm	ASTM D5185m	>3	0	0	0
Aluminum	ppm	ASTM D5185m	>9	6	4	4
Lead	ppm	ASTM D5185m	>30	2	<1	1
Copper	ppm	ASTM D5185m	>35	5	3	3
Tin	ppm	ASTM D5185m	>4	<mark>/</mark> 8	<u> </u>	6
Vanadium	ppm	ASTM D5185m		0	<1	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		1	<1	1
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m		11	8	2
Calcium	ppm	ASTM D5185m		3478	2446	2751
Phosphorus	ppm	ASTM D5185m		603	426	466
Zinc	ppm	ASTM D5185m		745	496	564
Sulfur	ppm	ASTM D5185m		3771	3101	3566
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>+100	61	46	53
Sodium	ppm	ASTM D5185m		18	12	13
Potassium	ppm	ASTM D5185m	>20	14	7	9
INFRA-RED		method	limit/base	current	history1	history2
					· · · · · ·	,
Soot %	%	*ASTM D7844		0.1	0.1	0.1
Soot % Nitration	% Abs/cm		>20	0.1 8.2		
		*ASTM D7844	>20 >30		0.1	0.1
Nitration	Abs/cm Abs/.1mm	*ASTM D7844 *ASTM D7624		8.2	0.1 8.0	0.1 8.1
Nitration Sulfation	Abs/cm Abs/.1mm	*ASTM D7844 *ASTM D7624 *ASTM D7415	>30	8.2 19.9	0.1 8.0 19.6	0.1 8.1 19.7
Nitration Sulfation FLUID DEGRADA	Abs/cm Abs/.1mm	*ASTM D7844 *ASTM D7624 *ASTM D7415 method	>30 limit/base	8.2 19.9 current	0.1 8.0 19.6 history1	0.1 8.1 19.7 history2




OIL ANALYSIS REPORT









Ê

etals	VISUAL		method	limit/base	current	history1	history2
	White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
	Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
	Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
	Silt	scalar	*Visual	NONE	NONE	NONE	NONE
	Debris	scalar	*Visual	NONE	NONE	NONE	NONE
A Ana	Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Jan 17/23 Mar6/23 Apr10/23	Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Jan1 Ma Apr1 May3	Odor	scalar	*Visual	NORML	NORML	NORML	NORML
	Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG
	Free Water	scalar	*Visual		NEG	NEG	NEG
•	FLUID PROPER	TIES	method	limit/base	current	history1	history2
NW	Visc @ 100°C	cSt	ASTM D445		14.9	13.9	13.9
V	GRAPHS						
	Iron (ppm)				Lead (ppm)		
	¹⁰⁰ Severe			5	0		
Jan 1 7/23 Mar6/23 Apr1 0/23	80 + 9 40 40 40 40 40 40 40 40 40 40			4	0		
Ar Ma	-∃ 60 Abnormal			틆3	0 - danormal		
	20			2			
				-			
~~/	Aug1/22 Sep26/22 Oct31/22	Mar6/23	Apr10/23 May30/23	Jul18/23	Aug 1/22 - Sep 26/22 - Oct3 1/22 -	Jan 17/23 Mar6/23 Apr10/23	Ma/30/23 Jul18/23
	Sep Au	Ma	Apr	Jul	Au Sep Oct	Jan Ma	May
	Aluminum (ppm)				Chromium (pp	m)	
	S				Smiara		
Jan 17/23 Mar6/23 - Apr10/23 - May30/23 -	E E E Abnormal			mdd	4 - Abnormal		
Jan1 Ma Apr1 May3	^[2] σ		~~~	1	2		
)°C		2 02					
	Aug1/22 Sep26/22 Oct31/22	an 17/23 Mar6/23	Apr10/23 May30/23	Jul18/23	Aug 1/22 Sep 26/22 Oct3 1/22	Jan17/23 Mar6/23 Aor10/23	May30/23
			Ma	- -	0,	el a d	Ma
	Copper (ppm)			20	Silicon (ppm)		
	60 -			15	0		
	E 40 - Abnormal			<u></u> [10	Abnormal		
	The second s						
/23 /23 /23	20-			5	U •		
Jan 17/23 Mar6/23 Apr10/23 May30/23	Jul18/23	23	23	23		23	23
	Jul Aug1/22 Sep26/22 Oct31/22	Mar6/23	Apr10/23 May30/23	Jul18/23	Aug1/22 Sep26/22	Jan 17/23 Mar6/23 Apr10/23	May30/23 Jul18/23
	Viscosity @ 100°C		-		Base Number		-
	Abnormal			10. (b)(HO) Baya Mumpar (mg) 2. 2. 0. 0. 0. 0. 0. 0. 0. 0. 0. 0. 0. 0. 0.	0 1		1111111111111
	16			8 KOH		~~	1
	ない 0014 初のmal	~~~~	~~~		- W	-	
	で 12 		+ + + + -	unn a 2	n T		
	10			^{se} B 0.			
	Aug1/22 Sep26/22 Oct31/22	Mar6/23	Apr10/23 May30/23	Jul18/23	Aug 1/22 Sep 26/22 Oct3 1/22	Jan17/23 Mar6/23 Apr10/23	May30/23 Jul18/23
	Sep Au	W	Api	Ju	Sep	Jar M	May
Laho	ratory : WearCheck USA -	501 Madis	son Ave Ca	rv. NC 2751	3	CUBE DIST	RICT ENERGY
ANAR Samp	ble No. : WC0835682	Received	: 22	Aug 2023			URSE SUITE 150
150/NCC 17025		Diagnose		Aug 2023		ALP	HARETTA, GA
	e Number : 10616931 Package : MOB 2	Diagnost	ician : Dor	n Baldridge		Contact: D	US 30005 YAN INGALLS
	le report, contact Customer Serv	vice at 1-8	00-237-1369	9.	rvan.ind		trictenergy.com
* - Denotes test meth	ods that are outside of the ISO 1	7025 sco	pe of accrea	litation.			(217)433-4972
Statements of conform	ity to specifications are based on t	the simple	acceptance of	decision rule ((JCGM 106:2012)		F: