

## [186544-N2STV4W] EXTRUDER Component

Parker

**Hydraulic System** ESSO NUTO H ISO 46 (--- GAL)

### Recommendation

Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



Sample Rating Trend



NORMAL

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PH05932122		
Sample Date		Client Info		31 Jul 2023		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		9639		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>20	<1		
Chromium	ppm	ASTM D5185m	>20	0		
Nickel	ppm	ASTM D5185m	>20	0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>20	<1		
Lead	ppm	ASTM D5185m	>20	0		
Copper	ppm	ASTM D5185m	>20	<1		
Tin	ppm	ASTM D5185m	>20	0		
Vanadium	ppm	ASTM D5185m		<1		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0		
Barium	ppm	ASTM D5185m	0	0		
Molybdenum	ppm	ASTM D5185m	0	0		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m	5	0		
Calcium	ppm	ASTM D5185m	50	51		
Phosphorus	ppm	ASTM D5185m	330	329		
Zinc	ppm	ASTM D5185m	410	409		
Sulfur	ppm	ASTM D5185m	2700	6355		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	<1		
Sodium	ppm	ASTM D5185m		0		
Potassium	ppm	ASTM D5185m	>20	0		
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	519		
Particles >6µm		ASTM D7647	>2500	72		
Particles >14µm		ASTM D7647	>320	12		
Particles >21µm		ASTM D7647	>80	4		
Particles >38µm		ASTM D7647	>20	1		
Particles >71µm		ASTM D7647	>4	0		
Oil Cleanliness		ISO 4406 (c)	>20/18/15	16/13/11		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.45	0.27		



# **OIL ANALYSIS REPORT**

NONE

NONE

NONE

NONE

NONE

NONE

NORML

NORML

NEG

NEG

42.8

no image


no image

no image

no imade

no imade

no image



ŝ 40 35

Laboratory

Sample No.

Lab Number

ul31

: PH05932122

: 05932122

Diagnostician : Doug Bogart Unique Number : 10617393 Test Package : PLANT (Additional Tests: PrtFilter) Contact: LOUIS STEIGERWALD III Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369. cgt@cathedralcandle.com \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

: WearCheck USA - 501 Madison Ave., Cary, NC 27513

Received

Diagnosed

Report Id: CATSYR [WUSCAR] 05932122 (Generated: 08/24/2023 13:25:02) Rev: 1

Contact/Location: LOUIS STEIGERWALD III - CATSYR

CATHEDRAL CANDLE COMPANY

**510 KIRKPATRICK ST** 

SYRACUSE, NY

T: (315)422-9119

US 13208

F:

Acid Number

e 0.20

Pg 0.00

Jul31/23.

: 23 Aug 2023

: 24 Aug 2023