



Area
PO-6030 [A13000314]
 Machine Id
QUINCY UN063286 - FEDEX
 Component
Compressor



COMPONENT CONDITION SUMMARY



RECOMMENDATION

Oil and filter change at the time of sampling has been noted. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS

Sample Status				ATTENTION	SEVERE	ATTENTION
Water	%	ASTM D6304	>0.1	▲ 1.76	● 24.8	---
ppm Water	ppm	ASTM D6304	>1000	▲ 17600	● 248000	---
Emulsified Water	scalar	*Visual	>0.1	▲ 0.2%	● 0.2%	NEG

Customer Id: UCPATLIT
 Sample No.: UCP05932170
 Lab Number: 05932170
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Don Baldrige +1
don.b505@comcast.net

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Fluid	---	---	?	Oil and filter change at the time of sampling has been noted.
Change Filter	---	---	?	Oil and filter change at the time of sampling has been noted.
Resample	---	---	?	We recommend an early resample to monitor this condition.

HISTORICAL DIAGNOSIS

11 Aug 2022 Diag: Doug Bogart

WATER



We advise that you check for the source of water entry. We recommend that you drain the oil and perform a filter service on this component if not already done. We recommend an early resample to monitor this condition. Please note that there was too much water present in the oil to perform an accurate viscosity test. All component wear rates are normal. Excessive free water present. There is a high concentration of water present in the oil. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The oil is no longer serviceable due to the presence of contaminants.

view report



15 Mar 2022 Diag: Jonathan Hester

ADDITIVES



We suspect abnormal metal contamination may be due to sampling method. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. Moderate concentration of visible metal present. All component wear rates are normal. There is no indication of any contamination in the oil. An additive depletion is indicated. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



28 Oct 2021 Diag: Jonathan Hester

ADDITIVES




Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. An additive depletion is indicated. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



Area
PO-6030 [A13000314]
 Machine Id
QUINCY UN063286 - FEDEX
 Component
Compressor



DIAGNOSIS

▲ Recommendation
 Oil and filter change at the time of sampling has been noted. We recommend an early resample to monitor this condition.

Wear
 All component wear rates are normal.

▲ Contamination
 There is a high concentration of water present in the oil.

Fluid Condition
 The AN level is acceptable for this fluid.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	UCP05932170	UCP05625758	UCP05498758
Sample Date	Client Info	15 Aug 2023	11 Aug 2022	15 Mar 2022
Machine Age	hrs	67621	65574	64283
Oil Age	hrs	65574	0	0
Oil Changed	Client Info	Changed	N/A	Not Changd
Sample Status		ATTENTION	SEVERE	ATTENTION

WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm ASTM D5185m >50	15	<1	<1
Chromium	ppm ASTM D5185m >10	0	0	0
Nickel	ppm ASTM D5185m	0	0	0
Titanium	ppm ASTM D5185m	0	0	0
Silver	ppm ASTM D5185m	0	<1	0
Aluminum	ppm ASTM D5185m >25	1	<1	<1
Lead	ppm ASTM D5185m >25	0	<1	0
Copper	ppm ASTM D5185m >50	2	1	<1
Tin	ppm ASTM D5185m >15	<1	<1	1
Antimony	ppm ASTM D5185m	---	---	---
Vanadium	ppm ASTM D5185m	<1	0	0
Cadmium	ppm ASTM D5185m	0	0	0

ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185m 0	2	2	2
Barium	ppm ASTM D5185m 700	196	▲ 31	▲ 79
Molybdenum	ppm ASTM D5185m 0	0	0	0
Manganese	ppm ASTM D5185m 0	<1	<1	0
Magnesium	ppm ASTM D5185m 0	2	0	0
Calcium	ppm ASTM D5185m 0	14	4	4
Phosphorus	ppm ASTM D5185m 0	10	7	5
Zinc	ppm ASTM D5185m 0	9	2	0
Sulfur	ppm ASTM D5185m 630	398	327	270




CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185m >25	5	6	11
Sodium	ppm ASTM D5185m	50	24	57
Potassium	ppm ASTM D5185m >20	8	2	<1
Water	% ASTM D6304 >0.1	▲ 1.76	● 24.8	---
ppm Water	ppm ASTM D6304 >1000	▲ 17600	● 248000	---

FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g ASTM D8045 0.200	1.19	0.20	0.14


OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	MODER
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	MODER	MODER
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	0.2%	0.2%
Free Water	scalar	*Visual	NEG	10.0	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D445	47.6	53.4	28.0	51.0

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : UCP05932170 **Received** : 23 Aug 2023
Lab Number : 05932170 **Diagnosed** : 24 Aug 2023
Unique Number : 10617441 **Diagnostician** : Don Baldrige
Test Package : IND 2 (Additional Tests: KF)

PATTONS INC - LITHONIA
 6709 TRIBBLE STREET
 LITHONIA, GA
 US 30058
 Contact: CHRISSY HARBIN
 chrissey.harbin@pattonsinco.com
 T: (770)484-9226
 F: (770)482-5522

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)