

KAESER COMPRESSORS Built for a lifetime:

KAESER 6810570

Component Compressor Fluid KAESER SIGMA (OEM) S-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We recommend you service the filters on this component. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS						
Sample Status			ABNORMAL	NORMAL	NORMAL	
Particles >6µm	ASTM D7647	>1300	<u> </u>	831	701	
Particles >14µm	ASTM D7647	>80	<u> </u>	13	29	
Particles >21µm	ASTM D7647	>20	<u> </u>	1	9	
Oil Cleanliness	ISO 4406 (c)	>/17/13	A 20/18/15	18/17/11	17/12	

Customer Id: UNISOFLO Sample No.: KC122712 Lab Number: 05932753 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Angela Borella +1 800-237-1369 angela.borella@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com



RECOMMENDED ACTIONS						
Action	Status	Date	Done By	Description		
Change Filter			?	We recommend you service the filters on this component.		

HISTORICAL DIAGNOSIS

NORMAI



No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



17 Aug 2021 Diag: Jonathan Hester

01 Sep 2022 Diag: Angela Borella



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN

level is acceptable for this fluid. The condition of the oil is suitable for further service.



NORMAL



10 Jul 2020 Diag: Angela Borella

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.







OIL ANALYSIS REPORT

Sample Rating Trend



KAESER 6810570 Component Compressor

Fluid KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Machine Id

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

SAMPLE INFORM	ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC122712	KC98902	KC94279
Sample Date		Client Info		31 Jul 2023	01 Sep 2022	17 Aug 2021
Machine Age	hrs	Client Info		8293	5260	3505
Oil Age	hrs	Client Info		0	2755	2400
Oil Changed		Client Info		N/A	Changed	Changed
Sample Status				ABNORMAL	NORMAI	NORMAI
oumpio otatao				,		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	0
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m	>10	<1	<1	0
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	5	4	8
Tin	ppm	ASTM D5185m	>10	0	0	<1
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
		mothod	limit/baca	ourropt	historyd	history
ADDITIVES		memou	IIIIII/Dase	Current	Thistory I	Thistory2
Boron	ppm	ASTM D5185m		0	0	<1
Barium	ppm	ASTM D5185m	90	0	<1	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	0	<1
Magnesium	ppm	ASTM D5185m	90	33	48	35
Calcium	ppm	ASTM D5185m	2	0	<1	0
Phosphorus	ppm	ASTM D5185m		4	2	0
Zinc	ppm	ASTM D5185m		0	4	0
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	maa	ASTM D5185m	>25	<1	<1	0
Sodium	ppm	ASTM D5185m		12	14	9
Potassium	ppm	ASTM D5185m	>20	3	3	3
Water	%	ASTM D6304	>0.05	0.021	0.024	0.024
ppm Water	ppm	ASTM D6304	>500	211.9	240.8	246.6
	IFSS	method	limit/base	current	history1	history2
	100		in in base	E 40E		0770
Particles >4µm		ASTM D7647	1000	5465	2194	2773
Particles >6µm		ASTM D7647	>1300	A 2065	831	701
Particles >14µm		ASTM D7647	>80	A 213	13	29
Particles >21µm		ASTM D7647	>20	<u> </u>	0	9
Particles >38µm		ASTM D7647	>4	1	0	0
Particles >/1 μ m		ASTM D/647	>3	0	0	0
Oil Cleanliness		ISO 4406 (C)	>/1//13	<u> </u>	18/1//11	17/12
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.33	0.35	0.318

2 COMPRESSORS

Built for a lifetime.

OIL ANALYSIS REPORT





VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	43.8	44.2	44.5
SAMPLE IMAGES		method	limit/base	current	history1	history2
Oslar						





Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: Service Manager - UNISOFLO

F: