


PROBLEM SUMMARY


Sample Rating Trend



Area
Thermoforming
Machine Id
Line 13 Extruder (S/N E2374)
Component
Bevel Helical Gearbox
Fluid
SUMMIT UNIPAR FG-320 (13 GAL)

COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

No corrective action is recommended at this time.
Resample at the next service interval to monitor. (Customer Sample Comment: Cs)

PROBLEMATIC TEST RESULTS

Sample Status			ATTENTION	NORMAL	ABNORMAL
Particles >4µm	ASTM D7647	>1300	▲ 1762	1241	---
Particles >6µm	ASTM D7647	>320	▲ 486	199	---
Oil Cleanliness	ISO 4406 (c)	>17/15/13	▲ 18/16/12	17/15/11	---

Customer Id: DARDALTX
Sample No.: TO50001786
Lab Number: 05932793
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Doug Bogart +1 (800)237-1369 x4016
dougb@wearcheckusa.com

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

05 Apr 2023 Diag: Doug Bogart

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



27 Feb 2023 Diag: Doug Bogart

DIRT



No corrective action is recommended at this time. Resample at the next service interval to monitor. Please note that this is a corrected copy for diagnostic comment updates regarding viscosity. All component wear rates are normal. Elemental level of silicon (Si) above normal. Viscosity of sample indicates oil is within ISO 320 range, advise investigate. Confirm oil type.

view report



09 Feb 2023 Diag: Doug Bogart

VISCOSITY




Resample at the next service interval to monitor. Please note that this is a corrected copy for diagnostic comment updates regarding viscosity. All component wear rates are normal. There is no indication of any contamination in the oil. Viscosity of sample indicates oil is within ISO 320 range, advise investigate. Confirm oil type.

view report



Area
Thermoforming
 Machine Id
Line 13 Extruder (S/N E2374)
 Component
Bevel Helical Gearbox
 Fluid
SUMMIT UNIPAR FG-320 (13 GAL)



DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor. (Customer Sample Comment: Cs)

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	TO50001786	TO50001548	TO50001406
Sample Date	Client Info	18 Aug 2023	05 Apr 2023	27 Feb 2023
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		ATTENTION	NORMAL	ABNORMAL

WEAR METALS

method	limit/base	current	history1	history2	
PQ	ASTM D8184	12	10	10	
Iron	ppm	ASTM D5185m >150	1	2	1
Chromium	ppm	ASTM D5185m >10	0	0	0
Nickel	ppm	ASTM D5185m >10	0	<1	0
Titanium	ppm	ASTM D5185m	0	0	<1
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >25	<1	0	0
Lead	ppm	ASTM D5185m >100	0	0	0
Copper	ppm	ASTM D5185m >50	<1	<1	<1
Tin	ppm	ASTM D5185m >10	0	0	0
Vanadium	ppm	ASTM D5185m	<1	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	0	0	0
Barium	ppm	ASTM D5185m	0	1	0
Molybdenum	ppm	ASTM D5185m	0	0	0
Manganese	ppm	ASTM D5185m	<1	<1	<1
Magnesium	ppm	ASTM D5185m	0	0	6
Calcium	ppm	ASTM D5185m	0	0	0
Phosphorus	ppm	ASTM D5185m	590	570	517
Zinc	ppm	ASTM D5185m	0	2	5
Sulfur	ppm	ASTM D5185m	634	507	437

CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >50	12	6	▲ 61
Sodium	ppm	ASTM D5185m	0	0	0
Potassium	ppm	ASTM D5185m >20	<1	<1	<1
Water	%	ASTM D6304 >0.1	0.00	0.005	---
ppm Water	ppm	ASTM D6304 >1000	0.00	52.8	---

FLUID CLEANLINESS


method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >1300	▲ 1762	1241	---
Particles >6µm	ASTM D7647 >320	▲ 486	199	---
Particles >14µm	ASTM D7647 >80	38	20	---
Particles >21µm	ASTM D7647 >20	10	9	---
Particles >38µm	ASTM D7647 >4	1	0	---
Particles >71µm	ASTM D7647 >3	0	0	---
Oil Cleanliness	ISO 4406 (c) >17/15/13	▲ 18/16/12	17/15/11	---

FLUID DEGRADATION


method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045	0.74	0.70	---

OIL ANALYSIS REPORT


▲ Particle Trend




Water




Viscosity @ 100°C



PQ




Viscosity @ 100°C







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	293	288	▲ 291
Visc @ 100°C	cSt	ASTM D445	26.5	26.2	▲ 26.5
Viscosity Index (VI)	Scale	ASTM D2270	118	118	119

SAMPLE IMAGES



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : TO50001786 **Received** : 23 Aug 2023
Lab Number : 05932793 **Diagnosed** : 27 Aug 2023
Unique Number : 10618064 **Diagnostician** : Doug Bogart
Test Package : IND 2 (Additional Tests: KF, KV100, PQ, PrtCount, VI)
 To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

DART CONTAINER CORPORATION
 4444 W LEADBETTER DR
 DALLAS, TX
 US 75236
 Contact: YON PALOMINO
 yon.palomino@dart.biz
 T: (214)775-5673
 F: