


## **OIL ANALYSIS REPORT**

### **Sample Rating Trend**



## NORMAL



# SHARPLES TYSDCR 2 ESH (S/N U6775 #2 SHARP)

Component

Bearing

**USPI SBO 68 (--- GAL)** 

רו	ΙΔ	(-1)	V۲	15	SIS
	-	ш	W	ノし	טוכ

#### Recommendation

Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable.

#### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

acidis Gudosi Facilisti Amplesis Mariesis Gudosi Gudosi Sudosz Mariesis									
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2			
Sample Number		Client Info		USPM29337	USPM28243	USPM26349			
Sample Date		Client Info		19 Aug 2023	13 May 2023	04 Feb 2023			
Machine Age	hrs	Client Info		0	0	0			
Oil Age	hrs	Client Info		0	0	0			
Oil Changed		Client Info		N/A	N/A	N/A			
Sample Status				NORMAL	NORMAL	NORMAL			
WEAR METALS		method	limit/base	current	history1	history2			
Iron	ppm	ASTM D5185m	>20	0	0	<1			
Chromium	ppm	ASTM D5185m	>20	0	0	0			
Nickel	ppm	ASTM D5185m	>20	0	<1	0			
Titanium	ppm	ASTM D5185m		0	0	0			
Silver	ppm	ASTM D5185m		0	0	0			
Aluminum	ppm	ASTM D5185m	>20	<1	<1	<1			
Lead	ppm	ASTM D5185m	>20	0	0	0			
Copper	ppm	ASTM D5185m	>20	0	0	<1			
Tin	ppm	ASTM D5185m	>20	0	0	0			
Vanadium	ppm	ASTM D5185m		<1	0	0			
Cadmium	ppm	ASTM D5185m		0	0	0			
ADDITIVES		method	limit/base	current	history1	history2			
Boron	ppm	ASTM D5185m		0	0	0			
Barium	ppm	ASTM D5185m		0	0	0			
Molybdenum	ppm	ASTM D5185m		0	0	0			
Manganese	ppm	ASTM D5185m		<1	<1	0			
Magnesium	ppm	ASTM D5185m		0	<1	<1			
Calcium	ppm	ASTM D5185m		0	<1	3			
Phosphorus	ppm	ASTM D5185m		40	41	31			
Zinc	ppm	ASTM D5185m		0	0	0			
Sulfur	ppm	ASTM D5185m		25	0	0			
CONTAMINANTS		method	limit/base	current	history1	history2			
Silicon	ppm	ASTM D5185m	>15	<1	0	<1			
Sodium	ppm	ASTM D5185m		0	<1	0			
Potassium	ppm	ASTM D5185m	>20	0	2	0			
Water	%	ASTM D6304	>2	0.001	0.00	0.002			
ppm Water	ppm	ASTM D6304		0.00	0.00	16.7			
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2			
Particles >4µm		ASTM D7647	>10000	1916	171	1460			
Particles >6µm		ASTM D7647	>2500	608	56	265			
Particles >14µm		ASTM D7647	>160	32	7	10			
Particles >21µm		ASTM D7647	>40	6	3	3			
Particles >38µm		ASTM D7647	>10	0	0	0			
Particles >71µm		ASTM D7647	>3	0	0	0			
Oil Cleanliness		ISO 4406 (c)	>20/18/14	18/16/12	15/13/10	18/15/10			
FLUID DEGRADA	TION	method	limit/base	current	history1	history2			
Acid Number (AN)	mg KOH/g	ASTM D8045		0.07	0.10	0.106			



## **OIL ANALYSIS REPORT**





Certificate L2367

Lab Number **Unique Number** 

: 05932811 : 10618082 Test Package : IND 2

: 24 Aug 2023 Diagnosed : Doug Bogart Diagnostician

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) US 68731

T: (605)235-2396

F: (605)235-2960

Contact: RICHARD KOCH